



Wake steering optimization under uncertainty

Julian Quick^{1,2}, Jennifer King², Ryan N. King², Peter E. Hamlington¹, and Katherine Dykes² ¹University of Colorado, Boulder, CO, USA ²National Renewable Energy Laboratory, Golden, CO, USA **Correspondence:** Julian Quick (julian.quick@colorado.edu)

Abstract. Turbines in wind power plants experience significant power losses when wakes from upstream turbines affect the energy production of downstream turbines. A promising plant-level control strategy to reduce these losses is wake steering, where upstream turbines are yawed to direct wakes away from downstream turbines. However, there are significant uncertainties in many aspects of the wake steering problem. For example, in-field sensors do not give perfect information and inflow

- 5 to the plant is complex and difficult to forecast with available information, even over short time periods. Here, we formulate and solve an optimization under uncertainty (OUU) problem for determining optimal plant-level wake steering strategies in the presence of uncorrelated uncertainties in the direction, speed, turbulence intensity, and shear of the incoming wind, as well as in turbine yaw positions. The OUU wake steering strategy is first examined for a two-turbine test case to explore the impacts of different types of inflow uncertainties, and is then demonstrated for a more realistic 11-turbine wind power plant. Of the
- 10 sources of uncertainty considered, we find that wake steering strategies are most sensitive to uncertainties in the wind speed and direction. The OUU strategy also tends to favor smaller yaw angles when maximizing expected power production. Ultimately, the plant-level wake steering strategy formulated using the OUU approach yields 0.48% more expected annual energy production than the deterministic strategy when considering stochastic inputs. Thus, not only does the present OUU strategy produce more power in realistic conditions, it also reduces risk by prescribing strategies that call for less extreme yaw angles.

15 1 Introduction

A key determinant in the profitability of a wind power plant is its annual energy production (AEP). The traditional strategy for increasing AEP has been to control each turbine in the plant such that single-turbine power generation is maximized, irrespective of the generation by other turbines. Plant-level control, by contrast, is an innovative approach that has the potential to further optimize wind plant performance and increase AEP (Johnson and Thomas, 2009; Marden et al., 2013; Gebraad et al.,

20 2017; Fleming et al., 2016a; Munters and Meyers, 2018). However, plant-level control presents new challenges in coordinating a set of complex machines, each operating in a highly uncertain and complex flow environment.

Recently, researchers from the National Renewable Energy Laboratory (NREL) have partnered with utility-scale wind power plants to demonstrate the potential benefits of the wind plant control strategy known as wake steering (Fleming et al., 2017, 2019). This strategy offsets turbine yaw positions from the incoming wind, which "steers" wakes away from downstream

25 turbines (Fleming et al., 2016b; Gebraad et al., 2016; Raach et al., 2016). Accurately characterizing the plant and atmospheric physics is, however, a significant challenge when designing wake steering schemes. In particular, it is difficult to forecast the





future behavior of the atmosphere since the engineering forecast models used in practice are prone to inaccuracies (Nygaard, 2015), in-field sensors are subject to bias (Mittelmeier and Kühn, 2018), and many quantities of interest must be extrapolated or interpreted from measured values.

There are also various sources of uncertainty that can have substantial impacts on the success of wake steering strategies. 5 Vertical mixing in the atmospheric boundary layer caused by temperature differences is difficult to measure and characterize (Wharton and Lundquist, 2010). Wind speed measurements must also be extrapolated horizontally to forecast conditions far away from sensors, as well as vertically to characterize the shear in the inflow and wind properties above meteorological measurement tower sensors (Clifton et al., 2016). Moreover, it is common practice to assume a deterministic relationship between turbine power, thrust coefficients, and wind speed, but there is large scatter in these values when they are measured in practice.

- 10 Complex phenomena, such as vorticity generated by the turbine blades, cause yaw alignment sensor errors, introducing significant uncertainty in measurements of turbine yaw angles relative to the incoming wind. Gaumond et al. (2014) showed that, by assuming uncertainty in the inflow direction, the predictive capability of engineering wake models may be improved. Although several studies have reported significant gains in AEP using plant-level control strategies under the assumption of perfect (i.e., certain) information (Gebraad et al., 2016; Fleming et al., 2016b; Bossanyi and Jorge, 2016), uncertainties associated with
- 15 wind plant model parameters may cause a wake steering strategy in the field to perform differently than anticipated. Uncertainty in the design process can be addressed using optimization under uncertainty (OUU), a technique that has been used in several prior wind plant optimization studies to provide a robust solution under varying levels of uncertainty (Gonzalez et al., 2012; Chen and MacDonald, 2013). Quick et al. (2017) formulated the wake steering problem using OUU, assuming large uncertainties in the yaw positions of individual turbines. Subsequently, Rott et al. (2018) formulated and solved a wake
- 20 steering OUU problem for a nine-turbine plant, assuming uncertainty in the measured inflow direction. More recently, Simley et al. (2019) formulated an OUU problem taking yaw position uncertainty and inflow direction variability into account.

In this paper, we extend prior work on OUU and plant-level control to address uncertainty in turbine yaw positions and inflow direction, speed, shear, and turbulence intensity during the optimization of turbine yaw offsets for wake steering strategies. In a two-turbine test case, we explore how different magnitudes of uncertainty impact the efficacy of wake steering schemes,

- 25 examining the trade-off between the power produced by the front and back turbines. Assuming standard uncertainty distributions based on available information, we find that the inflow speed and direction are the most influential parameters to the wake steering design problem. In a more realistic 11 turbine wind-plant test case, we further demonstrate the benefits of the OUU formulation. In particular, in addition to yielding more robust designs, the OUU formulation results in less-extreme prescribed yaw offsets.
- 30 The paper is organized as follows. In the next section, we outline details of the engineering wake model, the formulation of the OUU problem, and the specific application examined. Results are outlined for two-turbine and wind-plant test cases in Section 3, and conclusions are presented at the end.





2 Methodology, application, and approach

In this study, we applied the FLOw Redirection and Induction in Steady State (FLORIS) engineering wake model (NREL, 2019) to a simple two-turbine test case and to a more realistic 11-turbine wind plant to quantify potential benefits of explicitly taking uncertainty into account when designing plant-level wake steering schemes via OUU.

5 2.1 Engineering wake model

We used the FLORIS implementation of the Gaussian wake model (Bastankhah and Porté-Agel, 2016; Annoni et al., 2018), which imposes a velocity deficit given by

$$\frac{u(x,y,z)}{u_{\infty}} = 1 - C \exp\left[-\frac{(y-\delta)^2}{2\sigma_y^2} - \frac{(z-z_h)^2}{2\sigma_z^2}\right],\tag{1}$$

where u(x, y, z) is the velocity component in the direction of the inflow, x is the streamwise direction, y is the crossflow
direction, z is the vertical direction, δ is the deflection field, u_∞ is the inflow magnitude at the wind turbine hub height, z_h, and C is the velocity deficit in the center of the wake. The standard deviations σ_y and σ_z parameterize the width and height of the wake in the crossflow and vertical directions, respectively.

In this study, we limited the value of the thrust coefficient to be strictly less than one. Without this modification, wake calculations for low wind speeds may result in inaccurate predictions (in particular, the calculation of C involves the square

15 root of one minus the thrust coefficient). Throughout this paper, we use the NREL 5 MW reference turbine (Jonkman et al., 2009), which has power and thrust coefficient curves shown in Figure 1.



Figure 1. Power (solid line) and thrust coefficient (dashed line) as functions of wind speed for the NREL 5 MW reference turbine (Jonkman et al., 2009).



5

10



Problem formulation 2.2

Using the FLORIS wake model, the deterministic power production of a wind plant can be predicted given turbine-specific yaw positions, y, as well as the direction, θ , speed, u_{∞} , turbulence intensity, TI, and shear, α , of the incoming wind. We denote the deterministic power prediction from FLORIS as f(v), where $v = [y, \theta, u_{\infty}, TI, \alpha]$. It should be noted that y is a vector of yaw positions for each turbine in a farm and is a relative reference; in this sense, y represents a vector of yaw offsets with respect to θ . The length of the vector y is equal to the number of turbines in the plant. The inflow direction θ is measured clockwise from north and the yaw position is measured counterclockwise from the inflow direction.

During plant operation, inflow conditions and yaw misalignment are not perfectly known. These uncertainties stem from measurement error and aleatoric uncertainty. As a result, we introduce the stochastic expected power, denoted f_{10} because it is representative of uncertainties that are relevant on the order of 10 minutes of operational time. It is defined as

$$f_{10} := \int f(\boldsymbol{v}) p_v(\boldsymbol{v}) d\boldsymbol{v}, \qquad (2)$$

where $p_v(v)$ is a joint probability density function (pdf) that describes the distribution of v in the 10-minute period. Although this distribution can be empirically determined using real-world measurements and knowledge of turbines in a wind plant, in this study we instead parameterize p_v using the vector of mean values $\boldsymbol{\mu}_v = [\boldsymbol{\mu}_u, \mu_{\theta}, \mu_{u_{\infty}}, \mu_{\text{TI}}, \mu_{\alpha}]$, where μ_a denotes the

10-minute average value of variable a, and the hyperparameter vector Σ (which includes, for example, standard deviations if 15 p_v is assumed to be normally distributed). We thus parameterize f_{10} as

$$f_{10}(\boldsymbol{\mu}_{v},\boldsymbol{\Sigma}) = \int f(\boldsymbol{v}) p_{v}(\boldsymbol{v};\boldsymbol{\mu}_{v},\boldsymbol{\Sigma}) d\boldsymbol{v},$$
(3)

where $p_v(\boldsymbol{v};\boldsymbol{\mu}_v,\boldsymbol{\Sigma})$ denotes the joint pdf of \boldsymbol{v} parameterized by $\boldsymbol{\mu}_v$ and $\boldsymbol{\Sigma}$. We define this joint pdf such that, as $\boldsymbol{\Sigma} \to \mathbf{0}$, $p_v(\boldsymbol{v}; \boldsymbol{\mu}_v, \boldsymbol{\Sigma})$ approaches the Dirac delta function centered on $\boldsymbol{\mu}_v$, namely $\delta(\boldsymbol{v} - \boldsymbol{\mu}_v)$.

- The energy production may be estimated for a whole year (i.e., the expected AEP) as a linear sum of each speed- and 20 direction-specific expected power production, weighted by speed- and direction-specific probabilities and multiplied by 8,760 hours per year. These probabilities are representative of annual variability as opposed to the previously described uncertainty in operating conditions. Thus, the average inflow speed and direction are cast as being uncertain in order to capture their annual variability. In practice, these probabilities are empirically determined and jointly distributed. The resulting expression for AEP 25
- is thus given as

$$AEP(\boldsymbol{\mu}_{y}, \mu_{\mathrm{TI}}, \mu_{\alpha}, \boldsymbol{\Sigma}) = 8760 \int f_{10}(\boldsymbol{\mu}_{v}, \boldsymbol{\Sigma}) p_{\mu}(\mu_{u_{\infty}}, \mu_{\theta}) d\mu_{u_{\infty}} d\mu_{\theta}, \qquad (4)$$

where $p_{\mu}(\mu_{u_{\infty}},\mu_{\theta})$ represents the joint distribution of the 10-minute averages $\mu_{u_{\infty}}$ and μ_{θ} over a year.

Using Eq. (4) for the AEP, we can formulate the wake steering OUU problem as

$$\boldsymbol{\mu}_{y}^{(\text{OUU})} = \arg\max_{\boldsymbol{\mu}_{y}} \text{AEP}(\boldsymbol{\mu}_{y}, \boldsymbol{\mu}_{\text{TI}}, \boldsymbol{\mu}_{\alpha}, \boldsymbol{\Sigma}).$$
(5)

Similarly, the deterministic wake steering optimization is formulated for $\Sigma = 0$ as 30

$$\boldsymbol{\mu}_{y}^{(\text{det})} = \arg\max_{\boldsymbol{\mu}_{y}} \operatorname{AEP}(\boldsymbol{\mu}_{y}, \mu_{\text{TI}}, \mu_{\alpha}, \boldsymbol{0}).$$
(6)





Table 1. Summary of AEP-based metrics used to assess the quality of solutions for given values of μ_{TI} and μ_{α} (for simplicity, these parameters are suppressed as arguments of the AEP in the notation).

Metric	Equation	Description
VSS	$\operatorname{AEP}[\boldsymbol{\mu}_{y}^{(\mathrm{OUU})}, \boldsymbol{\Sigma}] / \operatorname{AEP}[\boldsymbol{\mu}_{y}^{(\mathrm{det})}, \boldsymbol{\Sigma}] - 1$	Stochastic AEP from OUU relative to the deterministic solution
VSS_b	$\operatorname{AEP}[oldsymbol{\mu}_y^{(\mathrm{OUU})}, oldsymbol{\Sigma}]/\operatorname{AEP}[oldsymbol{0}, oldsymbol{\Sigma}] - 1$	Stochastic AEP from OUU relative to the baseline solution
VDS	$\mathrm{AEP}[oldsymbol{\mu}_y^{(\mathrm{det})},oldsymbol{0}]/\mathrm{AEP}[oldsymbol{0},oldsymbol{0}]-1$	Nonstochastic AEP from the deterministic solution relative to the baseline solution
VDS_s	$\operatorname{AEP}[oldsymbol{\mu}_y^{(ext{det})}, oldsymbol{\Sigma}] / \operatorname{AEP}[oldsymbol{0}, oldsymbol{\Sigma}] - 1$	Stochastic AEP from the deterministic solution relative to the baseline solution

The baseline solution corresponds to turbines that are directly aligned with θ such that there is no yaw offset, corresponding to

$$\boldsymbol{\mu}_{\boldsymbol{u}}^{(\text{base})} = \boldsymbol{0}. \tag{7}$$

We used four metrics to assess the quality of different solutions for μ_y . The value of the stochastic solution (VSS) is the expected value of the stochastic AEP for the OUU solution relative to the deterministic solution. Our VSS definition is similar

- 5 to the VSS metric introduced by Birge and Louveaux (2011), but is expressed as a fractional increase in expected AEP rather than an absolute value increase. As a result, the solution value metrics do not depend on the amount of power produced. We also examined the expected value of stochastic AEP for the OUU solution relative to the baseline no-offset case, denoted VSS_b. The value of the deterministic solution (VDS) is the nonstochastic value of the AEP for the deterministic solution relative to the baseline solution. In addition, we report the stochastic value of the AEP for the deterministic solution relative to the baseline
- 10 solution, denoted as VDS_s . Each of these metrics is defined in Table 1.

2.3 Application

20

2.3.1 Uncertainty estimates

In the present demonstration tests, we considered the effects of uncertainty in turbine yaw offsets and wind inflow speed, direction, turbulence intensity, and shear. We envision wake steering strategies changing every 10 or 20 minutes, so we worked

to identify reasonable variations in each of these uncertain parameters over that time span. Together, these variations comprise the joint pdf $p_v(\boldsymbol{v}; \boldsymbol{\mu}_v, \boldsymbol{\Sigma})$.

To estimate the yaw position uncertainty, we compared operational data from an NREL turbine with a nearby meteorological measuring mast (NWTC Information Portal, 2019); these data were examined previously by Fleming et al. (2018), Annoni et al. (2018), and Damiani et al. (2018). In the present study, the wind direction recorded at the turbine was compared to the wind direction measured on the upstream meteorological mast. The mean error, which is sometimes referred to as bias, was removed

to focus on the shape of the distribution of errors, as shown in Figure 2.

Based on the shape of the distribution in Figure 2, we parameterize the yaw misalignment as a two-sided exponential distribution, termed the Laplace distribution, given by

$$L(x;\mu,\nu) = \frac{1}{2\nu} \exp\left(-\frac{|x-\mu|}{\nu}\right),\tag{8}$$







Figure 2. Errors in the yaw position y for a test turbine at the National Wind Technology Center at NREL (Fleming et al., 2018; Annoni et al., 2018; Damiani et al., 2018). The solid blue and green lines show Laplace and Gaussian distributions, respectively. The empirical probability mass function found from the observed yaw errors is shown with white bars.

where μ is the mean and ν is a shape parameter. The remaining uncertain parameters are assumed to be normally distributed according to

$$N(x;\mu,\sigma) = \frac{1}{\sqrt{2\pi\sigma^2}} \exp\left[-\frac{(x-\mu)^2}{2\sigma^2}\right],\tag{9}$$

where μ is again the mean and σ is the standard deviation. Each of the uncertain parameters are then assumed to be independent such that the joint pdf $p_v(\boldsymbol{v};\boldsymbol{\mu}_v,\boldsymbol{\Sigma})$ can be written as

$$p_v(\boldsymbol{v};\boldsymbol{\mu}_v,\boldsymbol{\Sigma}) = L(\boldsymbol{y};\boldsymbol{\mu}_y,\boldsymbol{\nu}_y)N(\theta;\mu_\theta,\sigma_\theta)N(u_\infty;\mu_{u_\infty},\sigma_{u_\infty})N(\mathrm{TI};\mu_{\mathrm{TI}},\sigma_{\mathrm{TI}})N(\alpha;\mu_\alpha,\sigma_\alpha),$$
(10)

where the hyperparameter is given as $\Sigma = [\nu_y, \sigma_\theta, \sigma_{u_\infty}, \sigma_{TI}, \sigma_\alpha]$. The vector ν_y represents the shape parameter used in the yaw offset Laplace distributions for each turbine in a plant. It should be noted that Mittelmeier and Kühn (2018) reported yaw misalignment to be a strong function of the inflow wind speed, which is not considered explicitly here.

10

5

- Estimated values for Σ are taken from a range of sources. Based on the observational data shown in Figure 2, we measured a shape parameter of $\nu = 6.16^{\circ}$, and we correspondingly set $\nu_y = 5^{\circ}$ for all turbines. Mittelmeier et al. (2017) discuss a methodology to estimate inflow conditions from turbine sensor data. They reported Gaussian uncertainties of 3.6° and 0.46 m/s when predicting the inflow direction and speed, respectively. Similarly, Gaumond et al. (2014) provided direction variations measured over a 10-minute interval in the Horns Rev power plant, which yielded a standard deviation of 2.67°. Based on
- these studies, we propose $\sigma_{\theta} = 5^{\circ}$ and $\sigma_{u_{\infty}} = 1$ m/s as reference uncertainty values. Lee and Lundquist (2017) provide lidar 15 observations of the turbulence intensity in front of a 1.5 MW turbine during evening transition. The late afternoon can be expected to have large turbulence intensities because that is when convection is strongest. Based on Figure 6 in Lee and Lundquist (2017), we estimate a large turbulence intensity standard deviation to be $\sigma_{TI} = 5\%$. The standard deviation in the shear parameter α is estimated to be $\sigma_{\alpha} = 0.05$, which represents a large, worst-case uncertainty for a 10-minute period.





Table 2. Probability distributions and hyperparameter values describing the uncertainty associated with various inputs to the wake model.

Parameter	Distribution	Hyperparameter
Yaw offsets, y	$L(\pmb{y};\pmb{\mu}_y,\pmb{\nu}_y)$	$\boldsymbol{\nu}_y = 5^{\circ}$
Wind direction, θ	$N(heta;\mu_ heta,\sigma_ heta)$	$\sigma_{\theta} = 5^{\circ}$
Wind speed, u_{∞}	$N(u_{\infty};\mu_{u_{\infty}},\sigma_{u_{\infty}})$	$\sigma_{u_{\infty}} = 1 \text{ m/s}$
Turbulence, TI	$N(\mathrm{TI};\mu_{\mathrm{TI}},\sigma_{\mathrm{TI}})$	$\sigma_{\rm TI} = 5\%$
Shear, α	$N(lpha;\mu_{lpha},\sigma_{lpha})$	$\sigma_{\alpha} = 0.05$

The resultant distribution choices and hyperparameter estimates are provided for each uncertain variable in Table 2. These distributions are intended to capture uncertainty associated with both physical variability and aleatoric uncertainty. It is cautioned that the magnitude of these sources of uncertainty are site specific. For example, a wind plant built in the wake of a large obstacle would be expected to have larger uncertainty in the inflow direction than a wind plant built offshore. As such, the

5 uncertainties outlined in Table 2 should be taken as representative of real uncertainties but do not correspond to any particular site or wind plant.

2.3.2 Calculation of AEP

We approximated the integral in Eq. (3) for f₁₀ using polynomial chaos expansion, which uses orthogonal polynomials with collocated quadrature points to interpolate a quantity of interest through an uncertain parameter space (Eldred and Elman, 2011). We used the polynomial chaos expansion tool in DAKOTA (Adams et al., 2014) in all cases. Padrón et al. (2019) recently demonstrated the advantages of polynomial chaos expansion in computing AEP as opposed to the traditional simple quadrature. When computing the integral in the two-turbine cases, we used fifth-order quadrature with uniform *p*-refinement and two maximum refinement iterations. In the OUU, we used fifth-order quadrature without refinement during each optimization iteration and used fifth-order quadrature with *p*-refinement and two maximum refinement levels to assess the outcome of the wind plant optimization OUU, deterministic, and baseline solutions.

During computation of the AEP via Eq. (4), the speed and direction joint pdf $p_{\mu}(\mu_{\theta}, \mu_{u_{\infty}})$ is approximated with an empirical discrete joint probability mass function, denoted $\rho_{\mu}(\mu_{\theta}^{d}, \mu_{u_{\infty}}^{i})$. Here, d = [1, ..., D] and i = [1, ..., I], where D is the number of directional bins and I is the number of inflow wind speed bins in the discrete function ρ_{μ} . This discretization thus yields a new definition of AEP, given as

$$20 \quad \text{AEP}(\boldsymbol{\mu}_{y}, \mu_{\text{TI}}, \mu_{\alpha}, \boldsymbol{\Sigma}) := 8760 \sum_{d=1}^{D} \sum_{i=1}^{I} \rho(\mu_{\theta}^{d}, \mu_{u_{\infty}}^{i}) f_{10}(\left[\boldsymbol{\mu}_{y}, \mu_{\theta}^{d}, \mu_{u_{\infty}}^{i}, \mu_{\text{TI}}, \mu_{\alpha}\right], \boldsymbol{\Sigma}).$$

$$(11)$$

2.3.3 Layouts considered

To demonstrate the benefits of OUU in the development of wake steering strategies, we considered a two-turbine layout as well as a larger 11-turbine layout. We used the two-turbine layout to explore the basic trade-off between the power production of front and back turbines as well as the sensitivity to different levels of uncertainty. The wind plant problem was used to assess





 Table 3. Mean value and lower and upper bounds used in two-turbine and wind plant OUU problems. Sequences are expressed as

 [start : increment : end].

Parameter	Two-turbines μ_i	Two-turbines Σ_i	Plant μ_i	Plant Σ_i	Lower Bound	Upper Bound
y (°)	[-30:1:30]	[1:1:15]	-	0	$-\infty$	∞
θ (°)	[-60:10:60]	[1:1:15]	[-60:10:60]	5	$-\infty$	∞
u_{∞} (m/s)	[3:1:15]	[0.2, 0.5, 1, 2]	[3:1:15]	1	3	20
TI (%)	6	[1:1:10]	6	0	1	30
α	0.12	[0.02, 0.05, 0.1, 0.15, 0.2]	0.12	0	-0.5	3.0



Figure 3. Contours of wind speed for a simple two-turbine test case with an inflow speed of 8 m/s. Brighter colors correspond to faster wind speeds. In (a), the turbines are both directly facing the wind with y set to 0. In (b), the front turbine is offset such that $y_1 = 30^\circ$ and $y_2 = 0^\circ$.

the potential benefits of OUU in a more realistic wind plant design problem. The mean values, shape parameters, and upper and lower bounds associated with each input considered in the two-turbine and wind plant cases are shown in Table 3.

In the two-turbine case, the front turbine directly wakes the back turbine when flow is from the north, as shown in Figure

5

3(a). The turbines are spaced five rotor diameters apart in the northern direction. We chose this case because it is representative of the fundamental trade-off between upstream turbines losing power by offsetting their yaw positions and downstream turbines gaining power when wakes are diverted away from them [as indicated in Figure 3(b)]. We performed a parameter sweep across possible values of the front turbine yaw offset with a nested sampling routine to find the optimum steering strategy for various uncertainties in the inflow. We report the maximum VSS across all directions and speeds for each uncertain input using the







Figure 4. Contours of wind speed for the 11-turbine wind farm with the baseline yaw configuration (y = 0) and 10 m/s inflow speed. Brighter colors correspond to faster wind speeds.

reference shape values. Uncertainties with maximum VSS larger than 0.5% were selected to be included in the wind farm OUU.

The wind farm wake steering optimization problem is intended to provide insights on the benefits of OUU in more realistic scenarios. The plant layout is shown in Figure 4, and the corresponding annual wind speed and direction probability mass

- 5 function is shown in Figure 5. We performed deterministic and stochastic wake steering optimizations for each speed and direction, reporting the deterministic and expected power production associated with the OUU, deterministic, and baseline strategies. We used the annual wind speed and direction probability mass function to aggregate these speed- and direction-specific power production estimates into an estimate of AEP. The expected power production was maximized during the optimization. The COBYLA optimization driver in DAKOTA (Adams et al., 2014) was used to design the wake steering
- 10 strategies. The polynomial chaos expansion tool in DAKOTA (Adams et al., 2014) was used during each optimization iteration to estimate the stochastic response in the OUU. Each OUU was initialized with the corresponding deterministic solution.

3 Results

In the following, we present results for OUU of the simple two-turbine case, as well as the 11-turbine wind plant. It will be shown from an analysis of the two-turbine case that wind speed and direction are the most influential parameters, and so we

and the results are compared to baseline strategies (i.e., using no wake steering).

15 performed the OUU using only these two uncertain variables, assuming ν_y , σ_{TI} , and σ_α to be zero. Optimization results of wake steering strategies for the 11-turbine wind plant are presented using the OUU and deterministic problem formulations,







Figure 5. Annual wind speed and direction probability mass function used in the 11-turbine wind plant optimization study.

Table 4. Maximum VSS across all speeds and directions considered, given the reference standard deviation values in Table 2.

Parameter	y	θ	u_{∞}	TI	α
$\max(\mathrm{VSS} \Sigma)$	0.32%	5.4%	0.60%	0.28%	0.02%

3.1 Two-turbine test case

Figure 3 shows results for the two-turbine test case, where the front turbine wakes the back turbine. For each uncertain parameter, we performed a parameter sweep across possible values of the front turbine yaw offset with a nested sampling routine to find the optimum steering strategy for various levels of uncertainty. The results are summarized in Table 4. Using a VSS

5 threshold of 0.5%, we found that the wind speed and direction are the most influential parameters and that shear, turbulence intensity, and yaw misalignment are less important.

Uncertainty in the wind direction affects the path that wakes behind wind turbines will follow. This can be thought of as spreading out the wake. This effect is explored in Figure 6, which shows that, as the inflow direction uncertainty increases, the wake becomes spread out such that the power of the back turbine is eventually completely insensitive to the yaw angle

- 10 of the front turbine. The effect of uncertainty in direction on the front turbine optimal yaw settings is dramatic. For example, in Figure 6(c), the optimal yaw offset is around 25° when there is perfect information. As mild uncertainty is introduced, however, the optimal front turbine yaw angle decreases. When large levels of uncertainty are introduced, the optimal setting switches to almost no steering. The optimal front turbine yaw offset is shown as a function of inflow direction for different levels of uncertainty in Figure 6(d). Once again, as uncertainty increases, the optimal yaw offset becomes more gradual and
- 15 less extreme.







Figure 6. Power production for the front (a), back (b), and both (c) turbines as a function of front turbine yaw offset in the two-turbine case with 10 m/s inflow 3° from north. Different line colors indicate different values of σ_{θ} , as indicated in panel (d), with brighter colors corresponding to larger σ_{θ} and, hence, greater uncertainty in inflow direction. The black crosses in panel (c) denote optimal front turbine yaw offset as a function of inflow direction for 7 m/s inflow.

It is interesting to note that the deterministic solution may be worse than the baseline solution if there is large uncertainty in the inflow wind direction. This is shown in Figure 7, which indicates that, as inflow direction uncertainty increases, there is less overall benefit to wake steering. Results for VSS_b in Figure 7(b) show that the increase in power production is reduced from around 10% to 1% as σ_{θ} increases from 1° to 15°. The VDS results in Figure 7(c) have a maximum of almost 15% and, by definition, are not affected by uncertainty. We found that the deterministic strategy performed on the order of 10% worse than the baseline solution for large levels of direction uncertainty, which may be observed in the VDS_s results shown in Figure

7(d).

5

Uncertainty in the incoming wind speed u_{∞} changes the magnitude of the wake velocity deficits, although the wake paths remain unchanged. When there is variability in the wind speed, the power produced by a wind turbine should generally increase

- 10 when there are lower wind speeds, in the cubic region of the power curve, and decrease when there are higher wind speeds. This is due to Jensen's inequality and the concavity of different sections of the power curve (Quick et al., 2016). In either case, the difference in expected power production will result in different deterministic and stochastic operational strategies. Figure 8 shows that uncertainty in lower inflow speeds caused the optimal front turbine angle to decrease, and uncertainty in higher wind speeds caused the optimal front turbine offset to increase. The optimal front turbine offset was insensitive to
- 15 wind speed uncertainty in the cubic range of the power curve. The increased uncertainty in the inflow speed changes expected power production, which changes the trade-off between reduced power from the upstream turbine and increased power from the downstream turbine due to yaw deflection.







Figure 7. Summary statistics from Table 1 for varying inflow direction θ and uncertainty σ_{θ} in the two-turbine case with 7 m/s inflow. Panels show VSS (a), VSS_b (b), VDS (c), and VDS_s (d), with different values of σ_{θ} indicated by different line colors (the legend is shown at the right of the figure).

Overall, we found this two-turbine case to be less sensitive to uncertainties in yaw misalignment, turbulence intensity, and wind shear. Uncertainty in the turbine yaw positions generally reduces the rotor swept area and spreads out the path of the turbine wake. As a result, the power of the back turbine may be increased or decreased by yaw misalignment uncertainty depending on which dynamic dominates. Yaw position uncertainty does not dramatically affect the solution at the reference uncertainty ($\nu_y = 5^\circ$), but produces a noticeably different solution near $\nu_y = 10^\circ$, which has a maximum VSS of 1.23%. Turbulence intensity affects the wake expansion geometry, which effectively smears out the path of wakes, decreasing the velocity deficit felt by waked turbines. Although we did not find turbulence intensity uncertainty to be significant here, we found a maximum VSS of 1.29% when $\sigma_{TI} = 10\%$. Such a large standard deviation in this truncated normal distribution approaches a uniform distribution, which could be thought of as representing a complete lack of information regarding turbulence intensity.

10 Introducing Gaussian uncertainty in the shear coefficient did not affect the optimum front turbine angle beyond one or two degrees, even at dramatic levels of uncertainty.

3.2 Wind plant test case

To quantify the benefits of OUU in a more realistic scenario, we also performed OUU to design wake steering strategies for an 11-turbine wind power plant. The stochastic average and deterministic AEP associated with the OUU, deterministic opti-

15 mization, and baseline (i.e., no wake steering) solutions are provided in Table 5. These represent the aggregate of the different optimization solutions, where powers are weighted by the speed- and direction-specific annual probabilities of occurrence







Figure 8. Power production for the front (a), back (b), and both (c) turbines as a function of front turbine yaw offset in the two-turbine case with 13 m/s inflow 7° from north. Different line colors indicate different values of $\sigma_{u_{\infty}}$, as indicated by the legend in panel (g), with brighter colors corresponding to larger $\sigma_{u_{\infty}}$ and, hence, greater uncertainty in inflow speed u_{∞} . The black crosses in panel (c) denote optimal front turbine yaw settings. Panels (d-g) show the optimal front turbine yaw offset as a function of inflow direction for inflow speeds u_{∞} of 10, 12, 13, and 14 m/s, respectively. Only positive inflow directions are shown to highlight the important effects of uncertainty.

shown in Figure 5. Table 5 shows that, given perfect information, the deterministic strategy is expected to produce 2.6% more AEP than the baseline strategy. However, for the present assumed input uncertainties, the deterministic strategy may be expected to perform comparably to the baseline strategy and the OUU strategy may be expected to produce 0.58% and 0.48% more AEP than the baseline and deterministic strategies, respectively.

5

It is interesting to note that the uncertain expected AEP is greater than the deterministic AEP in Table 5 for all three strategies. This represents the aggregate across the annual wind speed and direction probability mass function. We found that lower wind speeds (below 12 or 13 m/s) were generally associated with increased power production from uncertainty, while larger wind speeds yielded an expected power less than the deterministic value. When we only considered direction uncertainty, the expected power was consistently larger than its deterministic counterpart. This is because the wakes are inherently spread

 Table 5. Expected and deterministic AEP of OUU, deterministic, and baseline plant-level wake steering strategies for the 11-turbine wind plant test case.

	Expected AEP (GWh)	Deterministic AEP (GWh)
OUU optimization	115.2	113.3
Deterministic optimization	114.7	114.0
Baseline strategy	114.6	111.1





out by uncertainty in direction, reducing the expected velocity deficit in waked regions. When we only consider wind speed uncertainty, larger wind speeds were associated with decreased expected power, and smaller wind speeds were associated with increased expected power. This matches the intuition from Jensen's inequality discussed earlier.

Figure 9 summarizes improvements in AEP for the different wake steering strategies for varying wind speed and direction.
Some strategies appear to produce more than 15% more power given perfect inflow information [reflected in the VDS results in Figure 9(c)], but these same strategies produce almost 2% less power than the baseline no-steering strategy under uncertain conditions [shown in the VDS_s results in Figure 9(d)]. The VSS_b and VDS_s metrics in Figures 9(b) and (d), show that some deterministic and OUU solutions may produce 2% and 4% improvements in average power production, respectively, which is much lower than the increase predicted by the deterministic scenarios indicated in the VDS results shown in Figure 9(c). The optimization histories of the OUU and deterministic approaches are shown for 12 m/s inflow 30° from north in Figure 10.

In general, we found that by incorporating uncertainty in the wake steering problem formulation, less extreme yaw offsets were required to optimize AEP. We show the aggregate of yaw positions suggested by the OUU and deterministic optimization approaches in Figure 11. Although the histogram in Figure 11 is not weighted by probability of inflow occurrence, these results nevertheless strongly suggest that wind plant designers may expect OUU to yield wake steering strategies with lower-magnitude vary offsets than when using the deterministic optimization formulation.

15 yaw offsets than when using the deterministic optimization formulation.

4 Conclusions

In this study, we examined how uncertainty affects wake steering strategies and what benefits may be associated with designing these strategies in the presence of operational uncertainty using OUU. Uncertainty in yaw positions is epistemic and may be reduced with more accurate yaw position detection methods. Uncertainty in inflow conditions is more nuanced. While there

- 20 are issues with accurately measuring these quantities, fundamentally, there may not be a single characteristic direction, speed, turbulence intensity, or shear associated with the wind flowing into a utility-scale wind plant. For example, a wind power plant may be built downstream of a mountain, causing wind to enter from multiple directions. So, the uncertainties in these inflow parameters may be thought of as a combination of epistemic and aleatoric, irreducible, or model-form uncertainties.
- The fact that OUU results in more expected power production with less extreme yaw offsets makes a strong case for designers to move toward OUU formulations in plant-level control strategies. In particular, OUU results in wake steering strategies that are more conservative than the deterministic approach – the magnitude of the turbine yaw offsets determined by OUU is diminished compared to those found using deterministic optimization, even though the yaw positions are not part of the optimization objective. Assuming that the inflow uncertainties were precisely quantified, we have shown that wake strategies formulated with the OUU approach should produce up to about 4% more power than wake steering strategies formulated using
- 30 the deterministic approach.

We are optimistic for the future of plant control strategies and anticipate that uncertainty will become increasingly incorporated in future plant control analysis. In future work, we plan to further quantify typical levels of uncertainty in input parameters, explore higher-fidelity flow models, and to include fatigue loading in the OUU objective function. There are sev-







Figure 9. Summary statistics from Table 1 for varying inflow direction θ and wind speed u_{∞} in the 11-turbine wind plant test case. Panels show VSS (a), VSS_b (b), VDS (c), and VDS_s (d), with different values of u_{∞} indicated by different line colors (the legend is shown at the top).

eral other sources of uncertainty that may be injected into this problem. For example, we assumed perfect knowledge of the turbine power and thrust curves. Typical levels of uncertainty in turbine power and thrust curves probably would have resulted in somewhat different optimum wake steering strategies. Quantifying fatigue loading is an attractive prospect, though it requires a more advanced wake model. Partial waking may be more detrimental than full exposure to a wake, complicating the

5 fundamental trade-offs that we explored. The meandering behavior of wakes behind wind turbines is an important factor that is not captured by the steady-state FLORIS model.

Acknowledgements. This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Wind Energy Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes. The research was performed using







Figure 10. Optimization histories for deterministic (a) and stochastic (b) 11-turbine wind plant optimization studies with 12 m/s inflow 30° from north. The deterministic optimization was initialized with the baseline strategy and the stochastic optimization was initialized with the deterministic solution. The thick black line in each panel shows power (left vertical axes), and the thin multicolored lines show the yaw positions of the different turbines (right vertical axes).



Figure 11. Probability mass distributions of y summed over all turbines, wind speeds, and wind directions in the 11-turbine wind plant test case, as prescribed by the OUU and deterministic wind plant optimization strategies.

computational resources sponsored by the Department of Energy's Office of Energy Efficiency and Renewable Energy and located at the National Renewable Energy Laboratory.





References

Adams, B. M., Ebeida, M. S., Eldred, M. S., Geraci, G., Jakeman, J. D., Maupin, K. A., Monschke, J. A., Stephens, J. A., Swiler, L. P., Vigil, D. M., Wildey, T. M., Bohnhoff, W. J., Dalbey, K. R., Eddy, J. P., Frye, J. R., Hooper, R. W., Hu, K. T., Hough, P. D., Khalil, M., Ridgway, E. M., Winokur, J. G., and Rushdi, A.: Dakota, A Multilevel Parallel Object-Oriented Framework for Design Optimization, Parameter

5 Estimation, Uncertainty Quantification, and Sensitivity Analysis: Version 6.8 Theory Manual, 2014.

Annoni, J., Fleming, P., Scholbrock, A., Roadman, J., Dana, S., Adcock, C., Porte-Agel, F., Raach, S., Haizmann, F., and Schlipf, D.: Analysis of Control-Oriented Wake Modeling Tools Using Lidar Field Results, Tech. rep., National Renewable Energy Lab.(NREL), Golden, CO (United States), 2018.

Bastankhah, M. and Porté-Agel, F.: Experimental and theoretical study of wind turbine wakes in yawed conditions, Journal of Fluid Mechan-

10 ics, 806, 506–541, 2016.

Birge, J. R. and Louveaux, F.: Introduction to stochastic programming, Springer Science & Business Media, 2011.

Bossanyi, E. and Jorge, T.: Optimisation of wind plant sector management for energy and loads, in: Control Conference (ECC), 2016 European, pp. 922–927, IEEE, 2016.

Chen, L. and MacDonald, E.: Effects of uncertain land availability, wind shear, and cost on wind farm layout, in: Proceedings of the Interna-

- 15 tional Design Engineering Technical Conferences & Computers and Information in Engineering Conference IDETC/CIE, Portland, OR, USA, pp. 4–7, 2013.
 - Clifton, A., Smith, A., and Fields, M.: Wind plant preconstruction energy estimates: current practice and opportunities, National Renewable Energy Laboratory, NREL/TP–5000-64735, 2016.

Damiani, R., Dana, S., Annoni, J., Fleming, P., Roadman, J., Dam, J. v., and Dykes, K.: Assessment of wind turbine component loads under

20 yaw-offset conditions, Wind Energy Science, 3, 173–189, 2018.

Eldred, M. S. and Elman, H. C.: Design under uncertainty employing stochastic expansion methods, International Journal for Uncertainty Quantification, 1, 2011.

Fleming, P., Churchfield, M., Scholbrock, A., Clifton, A., Schreck, S., Johnson, K., Wright, A., Gebraad, P., Annoni, J., Naughton, B., et al.: Detailed field test of yaw-based wake steering, in: Journal of Physics: Conference Series, vol. 753, p. 052003, IOP Publishing, 2016a.

- 25 Fleming, P., Annoni, J., Shah, J. J., Wang, L., Ananthan, S., Zhang, Z., Hutchings, K., Wang, P., Chen, W., and Chen, L.: Field test of wake steering at an offshore wind farm, Wind Energy Science, 2, 229–239, 2017.
 - Fleming, P., Annoni, J., Martínez-Tossas, L. A., Raach, S., Gruchalla, K., Scholbrock, A., Churchfield, M., and Roadman, J.: Investigation into the shape of a wake of a yawed full-scale turbine, in: Journal of Physics: Conference Series, vol. 1037, p. 032010, IOP Publishing, 2018.
- 30 Fleming, P., King, J., Dykes, K., Simley, E., Roadman, J., Scholbrock, A., Murphy, P., Lundquist, J. K., Moriarty, P., Fleming, K., et al.: Initial results from a field campaign of wake steering applied at a commercial wind farm–Part 1, Wind Energy Science, 4, 273–285, 2019. Fleming, P. A., Ning, A., Gebraad, P. M., and Dykes, K.: Wind plant system engineering through optimization of layout and yaw control, Wind Energy, 19, 329–344, 2016b.

Gaumond, M., Réthoré, P.-E., Ott, S., Pena, A., Bechmann, A., and Hansen, K. S.: Evaluation of the wind direction uncertainty and its impact
on wake modeling at the Horns Rev offshore wind farm, Wind Energy, 17, 1169–1178, 2014.

Gebraad, P., Teeuwisse, F., Van Wingerden, J., Fleming, P. A., Ruben, S., Marden, J., and Pao, L.: Wind plant power optimization through yaw control using a parametric model for wake effects—a CFD simulation study, Wind Energy, 19, 95–114, 2016.





- Gebraad, P., Thomas, J. J., Ning, A., Fleming, P., and Dykes, K.: Maximization of the annual energy production of wind power plants by optimization of layout and yaw-based wake control, Wind Energy, 20, 97–107, 2017.
- Gonzalez, J. S., Payan, M. B., and Riquelme-Santos, J. M.: Optimization of wind farm turbine layout including decision making under risk, IEEE Systems Journal, 6, 94–102, 2012.
- 5 Johnson, K. E. and Thomas, N.: Wind farm control: Addressing the aerodynamic interaction among wind turbines, in: American Control Conference, 2009. ACC'09., pp. 2104–2109, IEEE, 2009.
 - Jonkman, J., Butterfield, S., Musial, W., and Scott, G.: Definition of a 5-MW reference wind turbine for offshore system development, National Renewable Energy Laboratory, Golden, CO, Technical Report No. NREL/TP-500-38060, 2009.
 - Lee, J. C. Y. and Lundquist, J. K.: Observing and Simulating Wind-Turbine Wakes During the Evening Transition, Boundary-Layer Meteo-
- 10 rology, 164, 449–474, https://doi.org/10.1007/s10546-017-0257-y, 2017.
 - Marden, J. R., Ruben, S. D., and Pao, L. Y.: A model-free approach to wind farm control using game theoretic methods, IEEE Transactions on Control Systems Technology, 21, 1207–1214, 2013.
 - Mittelmeier, N. and Kühn, M.: Determination of optimal wind turbine alignment into the wind and detection of alignment changes with SCADA data, Wind Energy Science, 3, 395–408, 2018.
- 15 Mittelmeier, N., Blodau, T., and Kühn, M.: Monitoring offshore wind farm power performance with SCADA data and an advanced wake model, Wind Energy Science, 2, 175–187, 2017.
 - Munters, W. and Meyers, J.: Dynamic strategies for yaw and induction control of wind farms based on large-eddy simulation and optimization, Energies, 11, 177, 2018.

National Renewable Energy Laboratory: FLORIS, https://github.com/NREL/FLORIS, 2019.

20 NWTC Information Portal: (NWTC 135-m Meteorological Towers Data Repository), https://nwtc.nrel.gov/135mData. Last modified 01-April-2015; Accessed 13-September-2019, 2019.

Nygaard, N. G.: Systematic quantification of wake model uncertainty, in: EWEA Offshore conference, pp. 10-12, 2015.

- Padrón, A. S., Thomas, J., Stanley, A. P., Alonso, J. J., and Ning, A.: Polynomial chaos to efficiently compute the annual energy production in wind farm layout optimization, Wind Energy Science, 4, 211–231, 2019.
- 25 Quick, J., Dykes, K., Graf, P., and Zahle, F.: Optimization Under Uncertainty of Site-Specific Turbine Configurations, Journal of Physics: Conference Series, 753, 062 012, http://stacks.iop.org/1742-6596/753/i=6/a=062012, 2016.
 - Quick, J., Annoni, J., King, R., Dykes, K., Fleming, P., and Ning, A.: Optimization Under Uncertainty for Wake Steering Strategies, Journal of Physics: Conference Series, 854, 012 036, http://stacks.iop.org/1742-6596/854/i=1/a=012036, 2017.
- Raach, S., Schlipf, D., Borisade, F., and Cheng, P. W.: Wake redirecting using feedback control to improve the power output of wind farms,
 in: American Control Conference (ACC), 2016, pp. 1387–1392, IEEE, 2016.
- Rott, A., Doekemeijer, B., Seifert, J. K., van Wingerden, J.-W., and Kühn, M.: Robust active wake control in consideration of wind direction variability and uncertainty, Wind Energy Science, 3, 869–882, https://doi.org/10.5194/wes-3-869-2018, https://www.wind-energ-sci.net/ 3/869/2018/, 2018.

Science Discussions, 2019, 1–26, https://doi.org/10.5194/wes-2019-35, https://www.wind-energ-sci-discuss.net/wes-2019-35/, 2019.
 Wharton, S. and Lundquist, J.: Assessing atmospheric stability and the impacts on wind characteristics at an onshore wind farm, Tech. rep., Lawrence Livermore National Laboratory (LLNL), Livermore, CA (United States), 2010.

Simley, E., Fleming, P., and King, J.: Design and Analysis of a Wake Steering Controller with Wind Direction Variability, Wind Energy