

Interactive comment on “Subsea cable management: Failure trending for offshore wind” by Charlotte Strang-Moran

Daniel Aitken

daniel.aitken@sse.com

Received and published: 31 March 2020

Line 49 - Creyke Beck is no longer being used, Dogger Bank A, B and C - <https://doggerbank.com/downloads/Dogger-Bank-name-change.pdf>

Line 171 - LCoE has been used as opposed to CFD values? Is there reasoning for this? Also for IACs has the position of the fault on the string been considered?

Section 4.3 - Does installation consider the transport and storage of the cables? Cables which have been onloaded/offloaded multiple times would appear to be at higher risk than where this has been limited, particularly with aluminium cored cables.

Line 220 - Is there a source for the 2-3m burial depth? This seems to be the top end for burial for IAC.

C1

Interactive comment on Wind Energ. Sci. Discuss., <https://doi.org/10.5194/wes-2020-56>, 2020.

C2