

Prognostics-based adaptive control strategy for lifetime control of wind turbines

Edwin Kipchirchir¹, M. Hung Do², Jackson G. Njiri³, and Dirk Söffker⁴

^{1,4}Chair of Dynamics and Control, University of Duisburg-Essen, Lotharstr. 1-21, 47057, Duisburg, Germany

²School of Heat Engineering and Refrigeration, Hanoi University of Science and Technology, No. 1, Dai Co Viet, Hai Ba Trung, Hanoi, Vietnam

³Department of Mechatronic Engineering, Jomo Kenyatta University of Agriculture and Technology, 62000-00200, Nairobi, Kenya

Correspondence: Edwin Kipchirchir (edwin.kipchirchir@uni-due.de)

Abstract. Variability of wind profiles in both space and time is responsible for fatigue loading in wind turbine components. Advanced control methods for mitigating structural loading in these components have been proposed in previous works. These also incorporate other objectives like speed and power regulation for above-rated wind speed operation. In recent years, lifetime control and extension strategies have been proposed to guaranty power supply and operational reliability of wind turbines.

5 These control strategies typically rely on a fatigue load evaluation criteria to determine the consumed lifetime of these components, subsequently varying the control set-point to guaranty a desired lifetime of the components. Most of these methods focus on controlling the lifetime of specific structural components of a wind turbine, typically the rotor blade or tower. Additionally, controllers are often designed to be valid about specific operating points, hence exhibit deteriorating performance in varying operating conditions. Therefore, they are not able to guaranty a desired lifetime in varying wind conditions. In this paper an

10 adaptive lifetime control strategy is proposed for controlled ageing of rotor blades to guaranty a desired lifetime, while considering damage accumulation level in the tower. The method relies on an online structural health monitoring system to vary the lifetime controller gains based on a State of Health (SoH) measure by considering the desired lifetime at every time-step. For demonstration, a 1.5 MW National Renewable Energy Laboratory (NREL) reference wind turbine is used. The proposed adaptive lifetime controller regulates structural loading in the rotor blades to guaranty a predefined damage level at the desired

15 lifetime without sacrificing on the speed regulation performance of the wind turbine. Additionally, significant reduction in the tower fatigue damage is observed.

1 Introduction

Growing demand for wind energy has led to the development of large wind turbines. However, these turbines are less tolerant to system performance degradation and faults (Gao and Liu, 2021). To ensure utility-scale wind turbines operate with respect
20 to their design lifetime, advanced control strategies have been developed in recent years to reduce structural loading of blades and tower. Most of these incorporate additional objectives such as power optimization and rotor speed regulation. The objective of lifetime control of wind turbines using prognostics-based load mitigation strategies has become more important in recent

years. Most of the proposed methods focus on controlling the lifetime of one structural component of a wind turbine, typically the rotor blade or the tower, without considering the fatigue damage level in other components. These lifetime controllers are 25 also designed to be valid about specific operating points.

A control strategy for extending the maintenance interval of wind turbine blades under assumed crack initiation, detected using a data filtering algorithm, is proposed (Beganovic et al., 2015). In (Beganovic et al., 2018; Njiri et al., 2019), a set of switching controllers with varying degrees of load mitigation are engaged sequentially based on the accumulated damage obtained from an online damage evaluation model to extend the lifetime of rotor blades. An adaptive lifetime controller is 30 proposed in (Do and Söfftker, 2020) to guaranty the desired lifetime of the tower. Depending on the damage accumulation and the predicted lifetime provided by a online damage evaluation model, the weights of the lifetime controller are varied. However, in (Beganovic et al., 2015, 2018; Njiri et al., 2019; Do and Söfftker, 2020) fatigue damage is considered in only one turbine component. The lifetime controllers used are not adaptive to varying wind conditions. In recent times, resilient control has been proposed in (Acho et al., 2016; Azizi et al., 2019; El Maati and El Bahir, 2020; Jain and Yamé, 2020) to minimize the effect of 35 unanticipated faults or unexpected dynamics to maintain the operation of a wind turbine within a limited degradation tolerance bound. However, resilient control does not address the problem of controlling life consumption in wind turbine components to avoid early fatigue failures. Although new concepts like operational modal analysis (OMA), which relies on measurement data to analyze vibrating structures are becoming the industry standard for condition monitoring and diagnosis especially for offshore wind turbines (Kim et al., 2019; Bajrić et al., 2018; Dong et al., 2018; Pegalajar-Jurado and Bredmose, 2019), these 40 concepts are yet to be integrated for prognosis and lifetime control of wind turbines.

In this work an adaptive lifetime control strategy is proposed for controlling ageing of rotor blades to guaranty a desired lifetime while considering damage accumulation level in the tower. A robust disturbance accommodating control (RDAC) proposed in (Do and Söfftker, 2022) is used for rotor speed regulation and load mitigation in the tower, while a prognostics-based adaptive independent pitch control (aIPC), which adapts to wind speed variation, is used for lifetime control of rotor 45 blades. By monitoring the accumulated damage using an online structural health evaluation model, the load mitigation level in the blades is controlled by varying the control gains in the respective IPC controllers based on a threshold evaluation of the estimated lifetime. As an improvement to the approaches in the aforementioned contributions, the proposed adaptive lifetime control strategy regulates fatigue loading in the rotor blades to reach a predefined damage limit at the desired lifetime with subsequent reduction in tower damage accumulation. This is realized without trade-off in speed/power regulation performance. 50 Although, the proposed lifetime control strategy is applied to wind turbine operations in above-rated operation, this concept can be extended for lifetime control in below-rated operation with suitable objectives including reducing structural loads while ensuring maximum power extraction as proposed in (Do and Söfftker, 2020).

The paper is organized as follows. In section 2, a theoretical background on wind turbine health monitoring is given. In section 3, design of the primary RDAC controller for rotor speed regulation and tower load mitigation, and the prognostics-based aIPC lifetime controller for controlled ageing of rotor blades is outlined. The proposed prognostics-based adaptive lifetime control strategy, which incorporates the primary and lifetime controllers, and an online damage evaluation model is 55 described in section 4. In section 5, simulation results based on performance evaluation of the proposed prognostics-based

adaptive lifetime control strategy on a reference wind turbine are discussed. Lastly, summary and conclusions are given in section 6.

60 2 Wind turbine health monitoring

Wind speed variability subjects wind turbine components like blades and tower to cyclic loading. This causes damage to be accumulated in these components overtime causing gradual degradation until failure occurs. Therefore, structural health monitoring of wind turbines is important in preventing occurrence of fatigue failure before reaching related design lifetime. Information on the damage evolution in a component can be utilized as a health indicator for failure detection as well as for 65 developing control measures to guaranty desired lifetime. This section outlines the methods used for estimating the damage accumulation in wind turbine components.

2.1 Evaluation of damage accumulation

A Wind turbine endure varying and complex load conditions over its lifetime. Fatigue analysis is therefore important in determining the consumed lifetime of its components. Component degradation starts at micro-scale as micro-cracks resulting from 70 irreversible changes in the microstructure, and propagates gradually until it fails. Assumptions of underlying damage evolution laws are often used to estimate the actual damage level as well as to predict the remaining useful life (RUL) of a component. Component-specific high-cycle fatigue experiments are used to generate S-N curves (Wöhler curve), which describe the relationship between applied stress amplitude S and the number of load cycles N that would cause failure. This forms the basis for the mathematical relation for fatigue analysis in wind turbines components expressed as

$$75 \quad s^m N = K, \quad (1)$$

where s denotes the stress range amplitude, m the Wöhler exponent (typically 3 for steel materials like the tower and 10 for composites like the blade (Ragan and Manuel, 2007)). The material parameter of fatigue damage at failure K e.g., ultimate tensile strength is related to the number of load cycles N .

Wind turbine components are designed for a service lifetime of at least 20 years according to the international electrotechnical commission (IEC) standard, with these structural components facing roughly between 10^8 and 10^9 fatigue load cycles (Ziegler et al., 2018). The component lifetime is typically arrived at using the projected number of fatigue cycles and average wind conditions it will encounter in its lifetime. Additionally, the IEC standard specifies that a wind turbine component should be designed to maintain its structural integrity in case it experiences 50 year extreme wind events during its lifetime.

Fatigue damage in components can be assessed using linear damage accumulation theory based on Miner's rule or nonlinear 85 damage accumulation theories (Yuan et al., 2015). Due to its simplicity, Miner's rule (Miner, 1945) is widely used. Wind speed variability induces varying-amplitude load spectrum on wind turbine components. To use Miner's rule, the complex spectrum of varying load is often transformed using rain-flow counting (RFC) algorithm first proposed by (Matsuishi and Endo, 1968),

into simple uniform loading, from which stress range histograms can be extracted and used to assess the accumulated damage. A schematic of this procedure is shown in Fig. 1.




Figure 1. Conventional fatigue load estimation (Ragan and Manuel, 2007).

90 By combining RFC and Miner's rule, damage accumulation D_k is calculated as

$$D_k = \sum_{i=1}^k d_i = \sum_{i=1}^k \frac{n_i}{N_i} = \sum_{i=1}^k \frac{n_i s_i^m}{K}, \quad (2)$$

where k denotes the total number of related stress range histograms, d_i the incremental damage at the i^{th} stress range histogram, n_i the number of applied load cycles in each histogram bin, N_i the number of cycles to failure at the i^{th} stress range histogram, and s_i the applied load amplitude in each histogram bin. With continual load application, damage in a component progresses 95 from an undamaged state $D_k = 0$ to the point it is considered to have reached its end of life when the accumulated damage, $D_k = 1$. In this case, the component is considered to have exhausted its structural reserves. Although other cycle counting algorithms including level crossing counting, peak counting, and simple range counting exist, RFC algorithms are the most widely applied for fatigue analysis (Musallam and Johnson, 2012).

2.2 Online rain-flow counting

100 Most standard RFC algorithms generate equivalent load cycles from complex load spectra by pairing local minima and maxima points using 3-point counting rule. Therefore, the entire load history is needed beforehand for the equivalent cycles to be generated. This process is computationally inefficient because the algorithm has to process all the stored loading data. Therefore, standard RFC cannot be used for real-time monitoring or control of life consumption of a component (Musallam and Johnson, 2012).

105 In (Musallam and Johnson, 2012), a real-time implementation of the RFC algorithm is proposed. By employing a 3-point counting rule recursively, the extremal points of time-series loading data are processed and stored in two flexible stacks as they occur to pick out the full and half cycles. For each identified cycle, and using Miner's rule, the life consumption of a component is then calculated and incremented online. This allows for the online determination of the consumed life of a component as well 110 as implementation of lifetime control. In this paper, the online damage evaluation algorithm (Musallam and Johnson, 2012), is adopted for evaluating the accumulated damage in rotor blades and tower. This information is then used to adapt the lifetime controller to guaranty a predefined service life of the wind turbine components.

3 Control strategy for load mitigation and speed regulation

115 In this paper, the robust disturbance accommodating controller (RDAC) controller (Do and Söfftker, 2022), proposed for rotor speed regulation and mitigation of tower fore-aft bending moments is extended to include an adaptive independent pitch controller (aIPC), which is used as a dynamic lifetime controller for reducing blade flap-wise bending moments in a wind turbine operating in the above-rated wind speed region. In this section the description of the reference wind turbine (RWT) is outlined. Additionally, the description of the adaptive robust observer-based controller, which is adapted for lifetime control, is summarized.

3.1 Wind turbine model description

120 A 1.5 MW WindPACT reference wind turbine developed by NREL (Rinker and Dykes, 2018), which is domicile in fatigue, aerodynamics, structures, and turbulence (FAST) design code (Jonkman and Buhl Jr., 2005), is chosen as the test-bed for the design and simulation of the proposed adaptive lifetime control strategy. This onshore wind turbine model was developed based on a real-life commercial wind turbine used in the WindPACT program. The specifications of this turbine are summarized in Table 1. It is a 3-bladed, upwind, horizontal axis wind turbine, having 24 degrees of freedom (DoFs) describing its flexibility. 125 However, a few DoFs are enabled to obtain a reduced order linear time-invariant (LTI) models used for controller design.

The nonlinear generalized equation of motion for the wind turbine is expressed as

$$M(q, u, t)\ddot{q} + f(q, \dot{q}, u, u_d, t) = 0, \quad (3)$$

130 where M denotes the mass matrix containing inertia and mass components and f is a nonlinear function of the enabled DoFs q and their first derivative \dot{q} , as well as the control input u , the disturbance input u_d , and time t . The nonlinear model Eq. (3) available in FAST is linearized about an operating point in the above-rated region. By enabling the DoFs, which capture the most important wind turbine dynamics of interest, and specifying the operating point defined by a constant hub height wind speed, pitch angle, and rotor speed, linearization is carried out numerically in FAST yielding periodic (azimuth dependent) matrices of LTI models.

Table 1. 1.5 MW WindPACT reference wind turbine specifications

Parameter	Value	Unit
Rated rotor speed	20.463	rpm
Hub height	84.288	m
Cut-in, Rated, Cut-out wind speed	4, 12, 25	m s^{-1}
Gearbox ratio	87.965	-
Blade radius	35	m
Rated power	1.5	MW
Blade pitch range	0-90	$^{\circ}$
Pitch rate	10	$^{\circ} \text{ s}^{-1}$
Optimal Tip-Speed-Ratio (λ_{opt})	7.0	-
Maximum power coefficient ($C_{p_{max}}$)	0.5	-
Optimum pitch angle (β_{opt})	2.6	$^{\circ}$

3.2 Controller for load mitigation and speed regulation

135 An adaptive robust observer-based controller, which in combination with an online damage evaluation model used for lifetime control of wind turbine components, is briefly outlined.

3.2.1 Robust disturbance accommodating controller

The RDAC controller, proposed in previous work (Do and Söfker, 2022), is briefly outlined for principal understanding. To obtain an LTI model for controller design while avoiding unnecessary complexity in the linear model, six DoFs including tower 140 fore-aft bending in first mode, drive-train torsional displacement, blades 1, 2, and 3 flap-wise displacements in first mode, variable speed generator, and drive-train rotational flexibility are chosen. These DoFs capture the most important dynamics corresponding to the desired closed-loop performance with respect to load mitigation in wind turbine blades and tower as well 145 as generator speed regulation assuming also a flexible drive-train. The linear model is obtained by linearizing the nonlinear model Eq. (1) about an operating point in the above-rated wind speed region defined by a steady hub-height wind speed of $v_{op} = 18 \text{ m s}^{-1}$, a pitch angle of $\beta_{op} = 20^{\circ}$, and a rotor speed of $\omega_{op} = 20.463 \text{ rpm}$. The states x used for controller design are

$$x = \begin{bmatrix} \text{tower-top fore-aft displacement} \\ \text{drivetrain torsional displacement} \\ \text{blade 1 flap-wise displacement} \\ \text{blade 2 flap-wise displacement} \\ \text{blade 3 flap-wise displacement} \\ \text{generator speed} \\ \text{tower fore-aft velocity} \\ \text{drivetrain torsional velocity} \\ \text{blade 1 flap-wise velocity} \\ \text{blade 2 flap-wise velocity} \\ \text{blade 3 flap-wise velocity} \end{bmatrix} . \quad (4)$$

The obtained reduced-order LTI model is expressed in state-space form as

$$\begin{aligned} \dot{x} &= Ax + Bu + B_d d \\ y &= Cx, \end{aligned} \quad (5)$$

150 where A, B, B_d, C denote the state-space system, u the control input, which is the collective pitch angle, x the states, d the wind disturbance, and y the measured outputs, which include rotor speed and tower-top fore-aft bending moment.

The model Eq. (5) is augmented with a pitch actuator model, which accounts for the slow pitch actuator dynamics. To counteract wind disturbance effects, the model is extended with an assumed step disturbance waveform (Wright, 2003; Wright and Fingersh, 2008), which approximates sudden uniform rotor effective wind velocity fluctuations. To meet the rotor speed 155 regulation objective with zero steady-state tracking error, the model is further extended with a partial integral action.

To ensure closed-loop system stability, robustness and optimality, a mixed-sensitivity H_∞ norm of the closed loop transfer function is used as a cost function to optimize the disturbance accommodating controller (DAC) parameters including observer gain L_x , state controller K_x disturbance rejection controller K_d , and the integral gain K_i in a single step. The mixed sensitivity H_∞ optimization problem is formulated as

$$160 \quad R^* = \underset{R \in \mathcal{R}}{\operatorname{argmin}} \left\| \begin{bmatrix} W_1 S \\ W_2 R S \\ W_3 T \end{bmatrix} \right\|_\infty, \quad (6)$$

where R^* denotes the optimized controller, \mathcal{R} a set of controllers R that stabilize the plant. The weighting functions W_1 , W_2 , and W_3 are introduced to ensure desired robust performance while S , $R S$, and T denote the related sensitivity, control effort, and complementary sensitivity functions, respectively. The problem to find an optimal RDAC controller $RDAC^*$ is formulated as

$$165 \quad RDAC^* = \underset{RDAC \in \mathcal{R} DAC}{\operatorname{argmin}} \| G_{zd}(P, RDAC) \|_\infty, \quad (7)$$

where $RDAC$ denotes a set of controllers $RDAC$ that stabilize the generalized plant P , and G_{zd} is the transfer function from the exogenous inputs d to the controlled outputs z .

Nonsmooth H_∞ synthesis proposed in (Apkarian and Noll, 2006), used for problems with structural and stability constraints is applied to find an optimal controller $RDAC^*$ with robust gains L and K for tower load mitigation and rotor speed regulation.

170 It is implemented in MATLAB using *hinfStruct* command (Apkarian and Noll, 2017). In Fig. 2 application of the RDAC controller to the 1.5 MW NREL RWT is shown. An actuator transfer function is included in the generalized plant P , to account for the blade pitch actuator dynamics. Hub height wind disturbance d excites the wind turbine dynamics in above rated operation. Measurement outputs including rotor speed ω and tower fore-aft bending moment ζ are fed to the RDAC controller, which generates a collective pitch angle β as a control signal for regulating rotor speed at the rated value and for reducing 175 tower fore-aft bending moment oscillations. The RDAC controller is robust against modeling errors and wind disturbances. The desired trade-off between robust stability and performance is achieved by choosing suitable weighting functions W_{11} ,




Figure 2. RDAC for wind turbines.

W_{12} , and W_2 . To effect rotor speed response and ensure robustness against wind disturbances, W_{11} is designed as an inverted low-pass filter. To reduce the first mode of tower fore-aft oscillation, W_{12} is designed as an inverted notch filter centered at 2.56 rad/s. To reduce controller activity at high frequencies thereby increasing robustness, W_2 is chosen as high-pass filter.

180 Both objectives of rotor speed regulation and tower load reduction for wind turbines operating in above-rated wind speed region are met while ensuring robustness against modeling errors and wind disturbances. However, $RDAC^*$ is only valid within its design operating point and suffers performance deterioration outside this envelop. Additionally, its control input signal is a collective pitch angle, hence cannot be applied for reducing blade oscillations due to vertical wind shear, which can only be achieved through IPC control.

185 3.2.2 Adaptive independent pitch controller

This controller is desired to counteract periodic aerodynamic loading of the rotor blades due to vertical wind shear. It is designed to reduce 1P (0.333 Hz) blade flap-wise oscillations and is adaptive to change in the operating point due to horizontal wind speed fluctuations. Five IPC controllers, each designed to be operational over a particular wind speed bin in the above-rated

wind speed region, together with a switching mechanism based on the incoming wind speed are used to realize aIPC. The linear models, used for designing respective IPC controllers are extracted from the nonlinear wind turbine model Eq. (1) at different operating points as shown in Table 2. It is important to note that the steady wind speeds (together with associated pitch angle and rated rotor speed) are only used to define operating points for extracting linear state-space models used for designing each of the IPC controllers. However, a stochastic wind profile is used for excitation of the closed-loop dynamic response of the wind turbine. Predefined wind speed bins are only used for thresholding based on the incoming hub-height stochastic wind speed to establish the appropriate IPC controller to be utilized in continuous operation.

Table 2. Design operating points for the IPC controllers

IPC Controller	Wind speed bin [m s^{-1}]	Steady wind speed [m s^{-1}]	Blade pitch angle [$^{\circ}$]	Rotor speed [rpm]
1	12 - 15	14	13.10	20
2	15 - 17	16	16.75	20
3	17 - 19	18	19.83	20
4	19 - 21	20	22.47	20
5	21 - 25	22	24.84	20

To capture the most important dynamics with respect to blade load mitigation and speed regulation, four DoFs including blade flap-wise displacement in for each blade in the first mode and variable speed generator are chosen. Correspondingly, seven states x are included in the linear model used for designing the aIPC controller. To capture periodicity due to vertical wind shear, 24 equispaced azimuth positions are selected for linearization. To integrate this periodicity in controller design, 200 multi-blade coordinate (MBC) transformation proposed in (Bir, 2010) is used to transform blade dynamics from the rotating to the non-rotating frame. The MBC transformed reduced order models are then averaged to obtain a weakly periodic LTI model described in state-space form as

$$\begin{aligned} \dot{x} &= Ax + Bu + B_d d \\ y &= Cx + v, \end{aligned} \tag{8}$$

where A, B, B_d, C denote the state-space system, $u = [\Delta\beta_1 \Delta\beta_2 \Delta\beta_3]^T$ denotes the perturbed independent pitch angles, and d 205 the wind disturbance. The measurements y , which include the blade root flap-wise bending moment for each blade are assumed to be distorted with noise v .

Using linear quadratic gaussian (LQG) control method, Eq. (8) is used to design an observer-based controller. The full-state feedback controller K is designed using linear quadratic regulator (LQR) technique by minimizing the cost function

$$J_{QR} = \int_0^{\infty} (x^T Q x + u^T R u) dt, \tag{9}$$

210 while solving the algebraic Riccati equation (ARE) $A^T P + PA - PBR^{-1}B^T P + Q = 0$, assuming (A, B) is fully controllable. Here Q and R denote the state and control input weighting matrices respectively, whose elements are tuned to achieve the

desired dynamic response with respect to blade load mitigation and rotor speed regulation, while P is the solution to the ARE. To implement optimal full-state feedback control $u = K\hat{x}$ using estimated states \hat{x} , a Kalman state estimator is used to design the observer gain L by minimizing the state estimation covariance error $E((x - \hat{x})(x - \hat{x})^T)$, while solving the ARE
215 $AP_f + P_f A^T - P_f C^T R_f^{-1} C P_f + Q_f = 0$, assuming A, C is fully observable. Here, Q_f and R_f are process disturbance and measurement noise covariance matrices, respectively, while P_f is the solution to the ARE.

Figure 3 illustrates the implementation of one of the five IPC controllers. The wind profile d excites the dynamics of the wind turbine in the above-rated wind speed region. The perturbed blade root flap-wise bending moment measurements Δy_o are transformed from the rotating to the fixed coordinate frame of controller design, using an inverse MBC transformation matrix $T(\psi)^{-1}$, which relies on real-time rotor azimuth angle measurements ψ . The perturbed independent pitch angles $\Delta\beta_i$ are obtained by transforming the control input u back to the rotating frame using the MBC transformation matrix $T(\psi)$. By summing $\Delta\beta_i$ and the collective pitch angle β_c from the RDAC controller, the IPC signal β_i obtained.
220




Figure 3. Independent pitch controller

The five IPC controllers are designed following this procedure, each at a predefined operating point, to cover the entire range of operation in the above-rated regime. A switching mechanism is implemented to activate each controller at a predefined
225 operating range based on the incoming hub-height wind speed for system excitation using stochastic wind profile.

4 Control of wind turbine lifetime: An illustrative example using the 1.5 MW NREL reference wind turbine

To control the lifetime consumption in wind turbine blades, the adaptive robust observer-based controller (RDAC+aIPC), implemented using two control loops is combined with an online damage evaluation model as shown in Fig. 4. A wind profile excites the wind turbine dynamics in the above-rated regime. The RDAC controller (Do and Söffker, 2022), which is robust
230 against modeling errors generates the primary CPC signal for rotor speed regulation and tower load mitigation, while aIPC

is used as the lifetime controller to dynamically control the damage accumulation of the rotor blades. The IPC angles are perturbed about the CPC signal from RDAC, forming the control input u to the wind turbine.




Figure 4. Prognostics-based adaptive lifetime control

The blade-root flap-wise bending moment measurements y are logged into memory during simulation. The online damage evaluation model based on the real-time implementation of the RFC algorithm (Musallam and Johnson, 2012), calculates the accumulated damage at every time-step D_k . The estimated lifetime of the blade L_e used as a state-of-health (SoH) indicator, is calculated as

$$L_e = \frac{T_k}{D_k} D_d, \quad (10)$$

where T_k denotes the current time step while D_d denotes the accumulated damage at the design lifetime. At every time step T_k , the estimated RUL can be calculated as

$$RUL = L_e - T_k = T_k \left(\frac{D_d}{D_k} - 1 \right). \quad (11)$$

Based on the threshold evaluation of L_e , the load mitigation level in the respective IPC controllers is controlled by selecting the appropriate gains L and K every 10 milliseconds, which is the time interval chosen for lifetime threshold evaluation. For illustrative purposes a lifetime of 600 seconds is chosen. Three threshold levels are set such that if L_e is below the lower limit of the desired lifetime ($L_e < 580$), maximum gains of respective IPC controllers are selected to increase the blade load mitigation level. If L_e falls within a range of the desired lifetime ($580 \leq L_e \leq 620$), optimum gains, which strike a balance between load mitigation and speed regulation are selected. On the other hand, if the value of L_e is higher than the desired lifetime ($L_e > 620$), hence blade load mitigation level can be compromised, minimum gains are chosen.

It is important to note that two levels of switching are implemented as illustrated in Fig. 5. The first level, used for switching between different IPC controllers, is defined based on the incoming hub-height stochastic wind speed. Highly uncertain wind

250 turbine anemometer measurement should suffice as strict accuracy is not required for switching. Predefined wind speed bins are used for thresholding and activating a suitable IPC controller from the designed bank of controllers. This ensures that an appropriate IPC controller is used for the prevailing operating conditions. The second level of switching relies on a lifetime estimate of the blades obtained from the online damage evaluation model, to adapt both the full-state feedback gain K and observer gain L of the IPC controller activated in the first level of switching to achieve the targeted lifetime. The combined switching constitutes aIPC lifetime control.




Figure 5. aIPC switching implementation

255

5 Results and discussion

This section presents and discusses the simulation results obtained from evaluating the adaptive lifetime control strategy using the 1.5 MW NREL RWT in FAST design code. Following the IEC 61400-1 recommendation for fatigue load evaluation, a 600 seconds stochastic wind profile generated using TurbSim software (Jonkman and Kilcher, 2012) is used for closed-loop 260 system excitation. The full-field IEC Kaimal type A wind profile shown in Fig. 6a has a mean hub-height wind speed of 18 m/s, a turbulence intensity of 16 % at 15 m/s, and vertical wind shear with a power-law exponent of 0.2. Although such a high wind speed has a low occurrence probability, it drives the dynamics of the wind turbine from near rated to cut-off wind speeds. Therefore, it is useful for demonstrating the performance of the proposed control strategy over a wide range of wind turbine 265 operation. While blade edge-wise (E-W) and tower side-side (S-S) bending moments contribute to the total fatigue damage of the respective components, in this contribution, blade flap-wise (F-W) and tower fore-aft (F-A) bending moments are chosen since they are the main structural loads that drive fatigue damage of respective components in above-rated turbine operation. This sufficiently demonstrates the application of lifetime estimation of wind turbine components as a state-of health indicator to establish a trade-off between load mitigation and speed regulation, to guarantee a given damage at a desired lifetime.

The performance of the lifetime control scheme in different blade load mitigation scenarios is shown in Fig. 6b. As shown, 270 the adaptive lifetime control strategy controls the damage accumulation in the blades to reach the predefined damage limit at the desired lifetime of 600 seconds. While the control strategy with maximum load mitigation achieves the same desired result, the lifetime control scheme spreads the incremental damage accumulation over the entire operation window by dynamically switching between the different load mitigation levels.




Figure 6. Adaptive lifetime control performance

The baseline controller (without lifetime control) used for comparisons is RDAC combined with aIPC without lifetime 275 control, whereby switching in aIPC is only based on incoming wind speed. To evaluate the proposed controller in varying wind fields, six profiles with mean wind speeds of 18 m/s and 14 m/s, each having three seeds are used. The three wind profiles having a mean wind speed of 18 m/s are shown in Fig. 7a. A comparison in blade F-W bending moment load mitigation performance is shown in Fig. 7b. On average (for the three wind fields), adaptive lifetime controller achieves 9.39 % reduction in standard deviation compared with the baseline controller. Additionally, there is significant reduction in the accumulated 280 damage as shown in Fig. 7c.

Performance of the adaptive lifetime control strategy in mitigating tower loads is also evaluated. As illustrated in Fig. 8a, significant reduction in tower F-A oscillation is observed, with the average standard deviation reducing by 6.58 %. A reduction in tower damage accumulation can be seen in Fig. 8b. This shows that lifetime control of blades, which reduces 1P fatigue 285 loads, leads to reduced damage accumulation in tower due to 3P fatigue loads. To evaluate the performance of the proposed lifetime control scheme in load mitigation in different tower and blades load channels, damage equivalent load (DEL) analysis is carried out using MLife software (Hayman, 2012). Based on fatigue analysis carried out with results obtained using the 10 minute stochastic wind profile shown in Fig. 7a, the lifetime controller reduces DELs in the blade F-W and tower F-A as illustrated in Fig. 8c. No noticeable change in blade E-W DEL is achieved. However, a slight increase is seen in tower S-S DEL, which is attributed to a slight increase in pitch activity for improved load reduction.

290 Despite the adaptive lifetime controller achieving improved performance in reducing damage accumulation in both rotor blade and tower, it is important to ascertain that this does not compromise the speed/power regulation performance. To illustrate




Figure 7. Blade fatigue load mitigation for 18 m/s wind

this, the rotor speed and generator power are evaluated as shown in Fig. 9. With lifetime control, no notable change is realized 295 rotor speed regulation. Although a slight increase of 8.7 % in power standard deviation is noted, the generated power fluctuates within acceptable limits. The mean power is identical at 1560.13 kW and 1559.97 kW for the baseline and lifetime controllers, respectively. Improvement in both load mitigation and rotor speed regulation is achieved with insignificant additional pitch activity as illustrated in Fig. 9c. The average total pitch travel marginally increases by 0.13 %.

Given that an 18 m/s wind field realization has a low occurrence probability since wind turbines spend most of the time 300 operating near-rated wind conditions, the proposed adaptive lifetime control strategy is evaluated using a near-rated wind profile. For this, three IEC type C stochastic wind field realizations shown in Fig. 10a, each with a mean speed of 14 m/s and a turbulence intensity of 12 % at 15 m/s are used. Fatigue load mitigation performance of the proposed lifetime controller in the blades is evaluated against the baseline controller as illustrated in Fig. 10b. The lifetime controller achieves 10.1 % reduction in standard deviation in blade F-W bending moment. Additionally, significant reduction in the accumulated damage is achieved.

A reduction in tower fore-aft loading and damage accumulation is realized as shown in Fig. 11a. The standard deviation in 305 tower loading is reduced by 11.2 %. Fatigue analysis is carried out using simulation results based on the wind profiles shown in Fig. 10a. As illustrated in Fig. 11c, the adaptive lifetime controller achieves DELs reduction in all load channels except the slight increase in tower S-S DEL.




Figure 8. Tower fatigue load mitigation and DEL analysis for 18 m/s wind

Speed and power regulation performance of the proposed controller is also evaluated at near-rated wind conditions as shown in Fig. 12. With lifetime control, improvement is realized in both speed and power regulation, with the standard deviation in 310 rotor speed and generated power reducing by 1.3 % and 1.2 %, respectively. The mean power is identical at 1553.5 kW and 1553.73 kW for the baseline and lifetime controllers, respectively. Improvement in both load mitigation and speed regulation 315 comes with insignificant additional pitch activity as illustrated in Fig. 12c. The average total pitch travel increases slightly by 0.5 %. Therefore, the proposed adaptive lifetime control strategy performs well in near-rated wind conditions.

6 Summary and conclusion

In this paper, a prognostics-based adaptive control strategy for lifetime control of wind turbines is presented. A robust disturbance 315 accommodating controller (RDAC) designed using mixed sensitivity H_∞ control, is used as the primary controller for mitigating tower loads and regulating rotor speed using a CPC-signal. On the other hand, aIPC controller designed using LQG control method is used as a lifetime controller. The gains of each of its five IPC controllers are adapted based on the state of health of the rotor blades obtained using an online damage evaluation model to strike a compromise between lifetime control through load mitigation and speed regulation.




Figure 9. Speed/power regulation performance and pitch actuator usage for 18 m/s wind

320 Through simulation using a 1.5 MW wind turbine model, it is demonstrated that the adaptive lifetime control strategy controls the damage accumulation in the blades to guaranty a given damage limit at the desired lifetime. Reduction in accumulated damage in the tower is also realized. This can potentially be used for optimizing maintenance scheduling in wind farms by synchronizing ageing of wind turbine components, hence reducing O&M costs, and increasing operational reliability. Fatigue analysis indicates reduction of DELs in most load channels. This improvement is realized without compromise in the 325 speed/power regulation performance. The lifetime controller achieves these results without significant increase in pitch actuator duty cycle. In the future, adaptive lifetime control based on nonlinear damage accumulation models will be considered. Additionally, use of new concepts for state of health indicators such as change in modal parameters for structural health monitoring will be explored.

Code availability. Code is not publicy available and can not be shared.

330 *Author contributions.* DS and JGN proposed the original idea of combining an online damage evaluation model with a switching IPC load mitigation control scheme for lifetime extension of wind turbine blades. MHD and DS extended the work of JGN by developing an adaptive lifetime controller (RDAC) to control life consumption in the tower. Based on these ideas and with supervision from DS, EK developed an




Figure 10. Blade fatigue load mitigation for 14 m/s wind

adaptive lifetime controller (aIPC), which is adaptive to wind speed changes, and in which the gains of each IPC controller are adapted to dynamically control the damage accumulation of rotor blades while monitoring the life consumption of the tower. EK evaluated the prognostics 335 scheme (RDAC+aIPC) on a 1.5 MW RWT by running simulations and analysing obtained results. With valuable input from DS, EK wrote the manuscript. All authors contributed to this work from concept to manuscript stage.

Competing interests. The authors declare that they have no conflict of interest.

Acknowledgements. This work is partly supported through a scholarship awarded to the first author by the German Academic Exchange Service (DAAD) in cooperation with the Ministry of Education of Kenya, for his Ph.D. study at the Chair of Dynamics and Control, UDE, 340 Germany.




Figure 11. Tower fatigue load mitigation and DEL analysis for 14 m/s wind

References

Acho, L., Rodellar, J., Tutivén, C., and Vidal, Y.: Passive fault tolerant control strategy in controlled wind turbines, in: 2016 3rd Conference on Control and Fault-Tolerant Systems (SysTol), pp. 636–641, IEEE, Barcelona, Spain, <https://doi.org/10.1109/SYSTOL.2016.7739820>, 2016.

345 Apkarian, P. and Noll, D.: Nonsmooth H_∞ synthesis, IEEE Transactions on Automatic Control, 51, 71–86, <https://doi.org/10.1109/TAC.2005.860290>, 2006.

Apkarian, P. and Noll, D.: The H_∞ control problem is solved, Aerospace Lab, 13, –1, <https://doi.org/10.12762/2017.AL13-01>, 2017.

Azizi, A., Nourisola, H., and Shoja-Majidabad, S.: Fault tolerant control of wind turbines with an adaptive output feedback sliding mode controller, Renewable Energy, 135, 55–65, <https://doi.org/10.1016/j.renene.2018.11.106>, 2019.

350 Bajrić, A., Jan, H., and Rüdinger, F.: Evaluation of damping estimates by automated operational modal analysis for offshore wind turbine tower vibrations, Renewable Energy, 116, 153–163, <https://doi.org/10.1016/j.renene.2017.03.043>, 2018.

Beganovic, N., Njiri, J. G., Rothe, S., and Söffker, D.: Application of Diagnosis and Prognosis to Wind Turbine System Based on Fatigue Load, in: 2015 IEEE Conference on Prognostics and Health Management (PHM), pp. 1–6, IEEE, Austin, Texas, <https://doi.org/10.1109/ICPHM.2015.7245031>, 2015.

355 Beganovic, N., Njiri, J. G., and Söffker, D.: Reduction of structural loads in wind turbines based on adapted control strategy concerning online fatigue damage evaluation models, <https://doi.org/10.3390/en11123429>, 2018.




Figure 12. Speed/power regulation performance and pitch actuator usage for 14 m/s wind

Bir, G. S.: User's guide to MBC3: Multi-blade coordinate transformation code for 3-bladed wind turbine, Tech. rep., National Renewable Energy Laboratory (NREL), <https://www.nrel.gov/docs/fy10osti/44327.pdf>, 2010.

Do, M. H. and Söfftker, D.: Wind turbine lifetime control using structural health monitoring and prognosis, *IFAC-PapersOnLine*, 53, 12 669–

360 12 674, <https://doi.org/10.1016/j.ifacol.2020.12.1847>, 2020.

Do, M. H. and Söfftker, D.: Wind turbine robust disturbance accommodating control using non-smooth H_∞ optimization, <https://doi.org/10.1002/we.2663>, 2022.

Dong, X., Lian, J., Wang, H., Yu, T., and Zhao, Y.: Structural vibration monitoring and operational modal analysis of offshore wind turbine structure, *Ocean Engineering*, 150, 280–297, <https://doi.org/10.1016/j.oceaneng.2017.12.052>, 2018.

365 El Maati, Y. A. and El Bahir, L.: Optimal fault tolerant control of large-scale wind turbines in the case of the pitch actuator partial faults, *Complexity*, 2020, 1–17, <https://doi.org/10.1155/2020/6210407>, 2020.

Gao, Z. and Liu, X.: An overview on fault diagnosis, prognosis and resilient control for wind turbine systems, *Processes*, 9, 300, <https://doi.org/10.3390/pr9020300>, 2021.

Hayman, G.: MLife theory manual for version 1.00, Tech. rep., National Renewable Energy Laboratory(NREL), Golden, Colorado, <https://www.nrel.gov/wind/nwtc/assets/pdfs/mlife-theory.pdf>, 2012.

Jain, T. and Yamé, J.: Health-aware fault-tolerant receding horizon control of wind turbines, *Control Engineering Practice*, 95, 104 236, <https://doi.org/10.1016/j.conengprac.2019.104236>, 2020.

Jonkman, B. J. and Kilcher, L.: TurbSim user's guide: version 1.06.00, Tech. rep., National Renewable Energy Laboratory (NREL), Golden, Colorado, USA, <https://www.nrel.gov/wind/nwtc/assets/pdfs/turbsim.pdf>, 2012.

375 Jonkman, J. M. and Buhl Jr., M. L.: FAST user's guide, Tech. Rep. NREL/EL-500-29798, National Renewable Energy Laboratory (NREL), Golden, Colorado, USA, <https://www.nrel.gov/docs/fy06osti/38230.pdf>, 2005.

Kim, H.-C., Kim, M.-H., and Choe, D.-E.: Structural health monitoring of towers and blades for floating offshore wind turbines using operational modal analysis and modal properties with numerical-sensor signals, *Ocean Engineering*, 188, 106226, <https://doi.org/10.1016/j.oceaneng.2019.106226>, 2019.

380 Matsuishi, M. and Endo, T.: Fatigue of metals subjected to varying stress, *Japan Society of Mechanical Engineers*, 68, 37–40, 1968.

Miner, M. A.: Cumulative damage in fatigue, <https://doi.org/10.1115/1.4009458>, 1945.

Musallam, M. and Johnson, C. M.: An efficient implementation of the rainflow counting algorithm for life consumption estimation, *IEEE Transactions on Reliability*, 61, 978–986, <https://doi.org/10.1109/TR.2012.2221040>, 2012.

Njiri, J. G., Beganovic, N., Do, M. H., and Sööffker, D.: Consideration of lifetime and fatigue load in wind turbine control, *Renewable Energy*, 385 131, 818–828, <https://doi.org/10.1016/j.renene.2018.07.109>, 2019.

Pegalajar-Jurado, A. and Bredmose, H.: Reproduction of slow-drift motions of a floating wind turbine using second-order hydrodynamics and operational modal analysis, *Marine Structures*, 66, 178–196, <https://doi.org/10.1016/j.marstruc.2019.02.008>, 2019.

Ragan, P. and Manuel, L.: Comparing estimates of wind turbine fatigue loads using time-domain and spectral methods, *Wind engineering*, 31, 83–99, <https://doi.org/10.1260/030952407781494494>, 2007.

390 Rinker, J. and Dykes, K.: WindPACT reference wind turbines, Tech. rep., National Renewable Energy Laboratory (NREL), Golden, Colorado, USA, <https://www.nrel.gov/docs/fy18osti/67667.pdf>, 2018.

Wright, A. D.: Modern control design for flexible wind turbines, University of Colorado at Boulder, Golden, Colorado, USA, <https://www.proquest.com/openview/f8f93112e807853ee3cbc16d4c8a64e7/1?pq-origsite=gscholar&cbl=18750&diss=y>, 2003.

395 Wright, A. D. and Fingersh, L. J.: Advanced control design for wind turbines part I: Control design, implementation, and initial tests, Tech. Rep. NREL/TP-500-42437, National Renewable Energy Laboratory (NREL), Golden, Colorado, USA, <https://www.osti.gov/biblio/927269>, 2008.

Yuan, R., Li, H., Huang, H. Z., Zhu, S. P., and Gao, H.: A nonlinear fatigue damage accumulation model considering strength degradation and its applications to fatigue reliability analysis, <https://doi.org/10.1177/1056789514544228>, 2015.

Ziegler, L., Gonzalez, E., Rubert, T., Smolka, U., and Melero, J. J.: Lifetime extension of onshore wind turbines: A review covering Germany, 400 Spain, Denmark, and the UK, *Renewable and Sustainable Energy Reviews*, 82, 1261–1271, <https://doi.org/10.1016/j.rser.2017.09.100>, 2018.