

Response to Reviewers

Evaluation of different power tracking operating strategies considering turbine loading and power dynamics

F. PÖSCHKE H. SCHULTE

July 7, 2022

Thank you for taking the time to review our manuscript again!

I. RESPONSE TO REVIEWER 3 / CHIEF EDITOR

1) the article lacks a proper description of existing literature. This point has been raised for the reviewers but has not been addressed in-depth. I think that by addressing it properly, the paper could gain more quality and the discussions would highlight better the novelty of the work. That being said, I recommend that the authors address this point before a final decision.

The literature contained in the article was further extended. Specifically, the power tracking functionality from a wind farm perspective was addressed more in-depth (lines 33-42 & lines 331-335 in the marked-up manuscript below). For this, the following references were additionally introduced:

J. P. Goit and J. Meyers (2015): Optimal control of energy extraction in wind-farm boundary layers. *Journal of Fluid Mechanics*. doi:10.1017/jfm.2015.70

F. Campagnolo, V. Petrović, C. L. Bottasso and A. Croce (2016): Wind Tunnel Testing of Wake Control Strategies. 2016 American Control Conference (ACC). doi: 10.1109/ACC.2016.7524965

S. Boersma, B.M. Doekemeijer, P.M.O. Gebräad, P.A. Fleming, J. Annoni, A.K. Scholbrock, J.A. Frederik, and J-W. van Wingerden (2017): A Tutorial on Control-Oriented Modeling and Control of Wind Farms. 2017 American Control Conference (ACC). doi: 10.23919/ACC.2017.7962923

S.K. Kanev, F.J. Savenije, W.P. Engels (2018): Active wake control: An approach to optimize the lifetime operation of wind farms. *Wind Energy*. doi: 10.1002/we.2173

D. van der Hoek, S. Kanev, J. Allin, D. Bieniek, N. Mittelmeier (2019): Effects of axial induction control on wind farm energy production - A field test. *Renewable Energy*. doi: 10.1016/j.renene.2019.03.117

D. van der Hoek, J. Frederik, M. Huang, F. Scarano, C. S. Ferreira, J-W. van Wingerden (2022): Experimental analysis of the effect of dynamic induction control on a wind turbine wake. *Wind Energy Science*. doi: 10.5194/wes-7-1305-2022

Evaluation of different power tracking operating strategies considering turbine loading and power dynamics

Florian Pöschke¹ and Horst Schulte¹

¹School of Engineering I, Control Engineering, University of Applied Sciences HTW Berlin, Germany

Correspondence: Florian Pöschke (poeschke@htw-berlin.de)

Abstract. This work focuses on the design, implementation, and implications of different operational strategies for wind turbines when providing a power tracking functionality. Power tracking is necessary for the contribution to stabilization of the electrical grid. Specifically, two different operational strategies are used as the foundation for a model-based control design that allows the turbine to follow a given power demand. The first relies on keeping a constant rotational speed while varying the generator torque to match the power demand. The second approach varies both, the generator torque and rotational speed of the turbine equally to yield the desired power output. In the power reduction mode, both operational strategies employ the pitch to maintain the desired rotational speed of the turbine. The attainable power dynamics of the two closed-loop systems to varying power demands are analyzed and compared. Reduced-order models formulated as transfer functions and suitable for the integration into an upper-level control design are proposed. It is found that the first strategy involving only the generator torque while keeping a constant rotational speed provides significantly faster power control authority. Further, the resulting fatigue loading in turbulent wind conditions is discussed for the two operational strategies, where constant operational storage is emulated to enable a bidirectional variation of the power output. Without any additional load reducing control loops, the results suggest that the first operational strategy involving variation of the generator torque only is more favorable with regard to the resulting loading of the turbine structure. The simulation studies are conducted for the 5 MW reference turbine using FAST.

1 Introduction

The provision of ancillary services by wind turbines is an increasingly important functionality for a stable and reliable operation of the electric power system (van Kuik et al., 2016). These ancillary services may comprise features like the reaction to frequency deviations for balancing load variations at different timescales (Margaris et al., 2012; Rebello et al., 2020), or supporting black-start of the power system (Shan et al., 2020; Jain et al., 2020). Effectively, these concepts vary the active and reactive power injection to match the demands of the electric grid, and therefore active power control on a turbine level is involved. Power system studies usually consider the turbine as a variable and adjustable power source (Margaris et al., 2012). For participation in grid stabilization, local control loops may be designed on the turbine level resulting in a variation of the power output depending on the measured states of the electrical grid, see e.g., the droop-based approaches in (Margaris et al., 2012; Aho et al., 2013; Van de Vyver et al., 2016; Abouzeid et al., 2019) or the comparison of different approaches

in (Jain et al., 2020). Moreover, wind turbines may be clustered with other distributed power generators into a virtual power plant aiming for a coordinated response governed by a central control scheme. For the design and implementation of these control loops, knowledge about the attainable dynamics of the energy conversion system are necessary (Xin et al., 2013; Björk et al., 2021). As a result, simple models are needed capable of portraying the relevant dynamics emerging from power tracking 30 operation of wind turbines.

Apart from the benefits of a power tracking for the electrical grid, the power tracking functionality has been reported to possibly enhance wind turbine operation by limiting structural loading (Petrović and Bottasso, 2017) or reducing and balancing loads within a wind farm (Boersma et al., 2017; Kazda et al., 2018; Vali et al., 2019). **Axial induction control** is a method that alters the individual turbine operating point aiming for an optimization of the overall wind farm power production. To achieve 35 this, the turbine is either statically or dynamically derated (Boersma et al., 2017; van der Hoek et al., 2022). In the static case, the energy extraction of the upstream turbines is reduced to possibly increase the energy contained in the wind for the downstream turbines (Kanev et al., 2018; van der Hoek et al., 2022). Within the dynamic approach, an additional time-variable 40 signal is superimposed on the pitch angle command to induce additional turbulence and beneficially influence wake mixing and wake recovery (Goit and Meyers, 2015; Munters and Meyers, 2018; Frederik et al., 2020; van der Hoek et al., 2022). For the application of these schemes experimentally or in the field (Campagnolo et al., 2016; van der Hoek et al., 2019; Frederik 45 et al., 2020; van der Hoek et al., 2022), controllers are necessary capable of either statically or dynamically tracking a desired operating point on the power and thrust coefficient surfaces of the turbine.

On the wind turbine level, power tracking results in an enlarged operational range that needs to be coped by the wind turbine controller compared to the usual strategy that aims for a maximization of the power output in partial-load region and a limitation 45 of power above rated wind speed (Aho et al., 2016; Pöschke et al., 2020; Jain et al., 2020). The operating trajectory that results in the desired power output, however, is not unique and therefore depends on the choice of the operational scheme encoded in the control strategy. This can be illustrated by considering the generator power given as

$$p = \omega_g T_g \quad , \quad (1)$$

where ω_g and T_g are the rotational speed and generator torque, respectively. From (1), it is apparent that a variation of the 50 power output to the demand can be achieved by an adjustment of either the rotational speed, the generator torque, or both. Consequently, there is a need to study the implications of different operating strategies for power tracking as discussed in (Deshpande and Peters, 2012; Aho et al., 2013; Jeong et al., 2014; Mirzaei et al., 2014; Aho et al., 2016; Zhu et al., 2017; Lio 55 et al., 2018). All of the works address the nonunique distribution of possible operating points on the power conversion surface, where different objectives like constant rotational speed (Aho et al., 2013; Jeong et al., 2014; Mirzaei et al., 2014; Zhu et al., 2017; Lio et al., 2018), constant tip speed ratio (Mirzaei et al., 2014; Zhu et al., 2017; Lio et al., 2018) or minimum thrust coefficient (Zhu et al., 2017; Lio et al., 2018) may determine the operating trajectories enforced by the controller. Most of the works apply augmented versions of commonly-used control loops to enable the power tracking functionality by varying the the setpoints of the applied controller (Deshpande and Peters, 2012; Aho et al., 2013; Jeong et al., 2014; Aho et al., 2016; Zhu et al., 2017; Lio et al., 2018). Comparisons of the different operating strategies considering both, the power tracking accuracy

60 and the resulting loading of the wind turbine structure are drawn in (Jeong et al., 2014; Aho et al., 2016). As the wind turbine
is a nonlinear system governed by its aerodynamic properties, gain-scheduled PI control schemes are usually applied, that,
depending on the current pitch position, alter the feedback gains to accommodate the varying dynamical properties of the
turbine (and thereby implicitly relate the control input to the current wind speed). This relation of the current pitch position
to the expected dynamics is usually derived at the nominal operating points. A straightforward application of the same gain-
65 scheduled pitch control as for nominal operation will result in degraded dynamical performance (Galinos et al., 2019), as the
expected dynamics accommodated by the gain scheduling is different depending on the power operating point and the wind
speed due to the nonlinear nature of the wind turbine (Mirzaei et al., 2014). Therefore, model-based control concepts can
be used that explicitly shape the control gains in all desired operating points equally as discussed in (Mirzaei et al., 2014;
Inthamoussou et al., 2016; Pöschke et al., 2020). In this article, the loading of the turbine structure depending on the chosen
70 strategy is compared, where identical performance constraints determine the individual feedback gains used to obtain a similar
closed-loop disturbance rejection dynamics in both operating strategies despite being operated at different trajectories. This
aims for a mitigation of the effects introduced by the control algorithms, such that a plain comparison of the different operating
strategies can be conducted.

75 Additionally to the loading perspective, this paper aims to feed the discussion on the integration of dynamical turbine
models for control design and simulation studies of large-scale power systems and wind farms. The employed model-based
control framework allows to enforce similar turbine dynamics with respect to the wind in both investigated schemes, such that
fundamental properties only influenced by the operating strategy and subject to varying power demands may be revealed and
discussed. This is exploited to study the power tracking behavior of the two distinct strategies and derive simplified analytical
80 models of the turbine power output dynamics. These models are useful for portraying the turbine dynamics when participating
in large-scale power system simulations and control design.

The article is structured as follows: In Section 2 the rationale for the chosen operating strategies is discussed, while Section
3 covers the applied control design. The simulation results are discussed in Section 4, where both, the resulting loading and the
attainable power tracking dynamics are analyzed. The conclusion is drawn in Section 5.

2 Operating strategies

85 Two different operating strategies are chosen and compared. In the first strategy, termed **OS1**, the demanded power is achieved
by a variation of the generator torque only while keeping the rotational speed at its nominal value depending on the current
wind speed. Contrarily, in **OS2** the controller enforces a variation of both, the generator torque and rotational speed to meet the
power demand. Compared to other strategies involving the limited extraction of rotational energy to support frequency events,
the control strategies presented here are conceptualized to enable a permanent operation at the desired power level.

90 With $\omega_{\text{opt}}(v)$ and $T_{\text{opt}}(v)$ being the steady-state rotational speed and generator torque for partial and full load region de-
pending on the current effective wind speed v , and p_d is normalized desired power output of the turbine, the two strategies used

for turbine operation are formalized as follows

$$\begin{aligned}
 \text{OS1 : } & \begin{cases} p(v) = \omega_{\text{opt}}(v) T_{\text{opt}}(v) & \text{if } p_d = 1 \\ p(v) = \omega_{\text{opt}}(v) \underbrace{p_d T_{\text{opt}}(v)}_{=T(v,p_d)} & \text{if } p_d < 1 \end{cases} \\
 \text{OS2 : } & \begin{cases} p(v) = \omega_{\text{opt}}(v) T_{\text{opt}}(v) & \text{if } p_d = 1 \\ p(v) = \underbrace{\sqrt{p_d} \omega_{\text{opt}}(v)}_{=\omega(v,p_d)} \underbrace{\sqrt{p_d} T_{\text{opt}}(v)}_{=T(v,p_d)} & \text{if } p_d < 1 \text{ and } \sqrt{p_d} \omega_{\text{opt}}(v) \geq \omega_{\text{min}} \\ p(v) = \underbrace{l_{\omega}(v,p_d) \sqrt{p_d} \omega_{\text{opt}}(v)}_{=\omega(v,p_d)} \underbrace{\frac{\sqrt{p_d}}{l_{\omega}(v,p_d)} T_{\text{opt}}(v)}_{=T(v,p_d)} & \text{if } p_d < 1 \text{ and } \sqrt{p_d} \omega_{\text{opt}}(v) < \omega_{\text{min}} \end{cases} \quad (2)
 \end{aligned}$$

OS1 employs the generator to produce the desired power by a reduction of the torque directly proportional to the demand

95 p_d . In this strategy, the controller is set to enforce the same rotational speed irrespective of the power output demand p_d by an adjustment of the pitch. Contrarily, in OS2 a reduction of both, the rotational speed and the generator torque setpoints proportional to $\sqrt{p_d}$ are designed also incorporating regulation by pitching. The minimum rotational speed was limited to $\omega_{\text{min}} = 0.75$ (or 9.1 rpm for the 5 MW reference turbine) to avoid hitting the first tower eigenfrequency with the 3P excitation of the rotation; see the Campbell diagram for the reference turbine in (Jonkman and Jonkman, 2016). To achieve this, the 100 operating point depending factor $l_{\omega}(v,p_d) = \frac{\omega_{\text{min}}}{\sqrt{p_d} \omega_{\text{opt}}(v)}$ is introduced in (2). For a power tracking command of $p_d = 1$ in both strategies equally, the turbine is operated on the commonly considered operating trajectory trying to maximize the power extraction in partial load region and limiting the power to its rated value in full load region. The derating is designed to provide power reduction relative to the currently available power, such that for e.g., a power tracking command $p_d = 0.7$ aims for a 70% power production of the possibly extricable power from the wind. This applies for both, partial-load and full-load region 105 equally. If an operation at a constant power is desired, the power tracking command can be recalculated as a function of the currently available power.

3 Control design

The continuous description of the desired operational strategies encoded in (2) is discretized at 280 operating points each. The

110 steady-state inputs of the wind turbine are derived for the corresponding operating points, and subsequently, a linearization analysis using the built-in functionality of FAST (Jonkman and Jonkman, 2016) is conducted to capture the rotational dynamics at each point. The linearization points are chosen to represent discrete power output values at $p_d = [1, 0.75, 0.5, 0.25]$ at wind speeds covering a range from $v = [5.5, \dots, 25]$ m/s with a denser distribution of operating points around rated wind speed. The resulting linearization points on the power coefficient surface of the considered turbine for the different operational strategies are illustrated in Fig. 1. The operating strategies share a common operational concept for a power demand of $p_d = 1$ (Fig. 1 115 and Equation (2)), which represents the nominal operating strategy used in wind turbine control for energy maximization. Fig.




Figure 1. Linearization points on the power coefficient surface for the strategies OS1 & OS2.

1 shows that the introduction of reduced power modes enlarges the range of possible operating points and consequently the dynamical properties that the controller needs to cope with appropriately.

The identified linear model dynamics A_i, B_i, B_{di} gained by the linearization procedure are then interconnected to form an overall nonlinear description in a so-called Takagi-Sugeno structure, which is described as

$$120 \quad \dot{x} = \sum_{i=1}^N h_i(z) (A_i(x - x_{0i}) + B_i(u - u_{0i}) + B_{di}(d - d_{0i})) \quad , \quad (3)$$

where the state, input and disturbance of the system are given by the rotational speed ($x = \omega$), the generator torque and pitch angle ($u = [T, \beta]^T$) and the wind speed ($d = v$), respectively. The steady-state values of the state, input and disturbance in the linearization points are represented by x_{0i}, u_{0i} and d_{0i} , respectively. The framework is based on the definition of convex membership functions $h_i(z)$ spanning across the entire operational range, which blend the individual linear submodels in 125 operation depending on the current power output demand, operational strategy, and wind speed, i.e., $z = [\Delta p, n_{OS}, v]^T$.

The control scheme is built on a disturbance observer. The observer estimates the current effective wind speed by a measurement of the rotational speed, generator torque and pitch angle. The estimate is used to calculate the maximum currently available power. The wind speed reconstruction is achieved by augmenting the system description in (3) by an artificial effective wind speed, i.e., $\tilde{x} = [x, v]^T$, where the observer dynamics characterizing $\dot{\tilde{x}} = [\hat{x}, \hat{v}]^T$ is then given as

$$130 \quad \dot{\tilde{x}} = \sum_{i=1}^N h_i(z) \left(\begin{bmatrix} A_i & B_{di} \\ 0 & -\frac{1}{\tau} \end{bmatrix} \tilde{x} + \begin{bmatrix} B_i \\ 0 \end{bmatrix} u + L_i C (\tilde{x} - \hat{x}) \right) \quad . \quad (4)$$

The disturbance input gains B_{di} are used to construct the augmented system matrix, $C = 1$ represents the output matrix and $\tau = 4\text{s}$ assigns an artificial first-order disturbance model to the reconstructed wind state \hat{v} . The wind speed estimate \hat{v} provided by the observer is used in the calculation of the current operating conditions influencing the membership functions in the nonlinear modeling framework, i.e., $h = f(\hat{v})$. These membership functions are then used for the scheduling of the observer 135 dynamics in (4) and the control input of the system. The estimate determines both, a feedback $(-\sum_{i=1}^N h_i(z) K_i x)$ and a

feedforward term ($\sum_{i=1}^N h_i(z)u_{0i}$) in the control input of the turbine, such that the system input is given as

$$u = -\sum_{i=1}^N h_i(z)K_i x + \sum_{i=1}^N h_i(z)u_{0i} \quad . \quad (5)$$

To obtain the necessary feedback gains K_i and L_i that jointly shape the closed-loop system behavior in the different operating points, a linear matrix inequality approach (VanAntwerp and Braatz, 2000) to control design is conducted. It embeds the

140 feedback gain design into a convex optimization problem involving stability of the closed-loop dynamics. Using linear matrix inequality region constraints (Chilali and Gahinet, 1996), the eigenvalues characterizing the closed-loop properties of the wind turbine model dynamics within the complex plane are restricted. The region constraints are chosen identical for both operating strategies, effectively resulting in very similar operating behavior with respect to the disturbance rejection. A lot of classical problems from control theory can be recast into linear matrix inequality design constraints (Boyd et al., 1994; VanAntwerp
145 and Braatz, 2000), where the Takagi-Sugeno framework represents one possible way of obtaining the necessarily involved system description. Details about the applied control scheme and its design process for wind turbines are discussed in (Pöschke et al., 2020; Pöschke et al., 2022). Whereas in (Pöschke et al., 2020) several degrees of freedom including tower or drivetrain dynamics are considered and actively damped, the applied controller in this work uses the rotational dynamics as only degree of freedom and measured quantity similar to the experimental wind tunnel validation discussed in (Pöschke et al., 2022). The
150 model-based design process can be applied to widespread linearization points determined by the control engineer's choice of operational strategy.

Whereas in (Pöschke et al., 2020; Pöschke et al., 2022) OS1 is applied for the studies involving power tracking and load analysis, within this work OS2 is added. Effectively, this is achieved by introducing an additional variable as premise in the Takagi-Sugeno framework used for the nonlinear modeling of the turbine dynamics, i.e., $z_2 = n_{OS}$. This has no effect on the
155 general control approach but introduces an additional dimension in the operating space coped by the premise variables. Even though we present the two operational strategies separately to underline the comparison of resulting loading and power tracking dynamics, essentially the turbine is operated by one controller that is capable of blending and switching between the different strategies.

4 Results

160 Application of the described control scheme to the FAST (Jonkman and Buhl, 2005) implementation of NREL's 5 MW reference turbine (Jonkman et al., 2009) allows studying the impact of the two operational strategies on the loading and the response time for changes in the power output. The pitch speed is limited to 8 deg/s in all considered scenarios. In the following two sections, the discussed operational strategies are compared from two different perspectives. First, the loading of the turbine structure in turbulent wind for some components is analyzed as this influences the possible choice of operating trajectories
165 with regard to the overall cost of energy. Second, the response time of the power output to instantaneous changes in the power demand is compared for the two operational concepts. Due to the possibly fast dynamics needed in the range of milliseconds to




Figure 2. (a) Wind turbine rotational speed, (b) generator torque and (c) turbine power output in turbulent wind for OS1 and OS2 at 70% of power production, where additionally a 15 s ramp transition at 160 s from OS1 to OS2 and back at 195 s is shown. (c) 40 min power output time series in both operational strategies at 70% power production.

hours (Machowski et al., 2008), the attainable power dynamics of wind turbines is a crucial metric for a successful contribution to grid stabilizing services.

Essentially, the same controller is used for turbine operation in the two strategies. It is capable of blending between the 170 operational strategies as shown in Fig. 2. It is illustrated how the operational strategy is linearly varied from OS1 at 160 s to OS2 within 15 s, which results in a reduction of the rotational speed until matching the trajectory for the operation of the 175 turbine in OS2 only with the same wind excitation. Subsequently, the opposite change of operational strategy is conducted from 195 s to 210 s. While a small delay in the reduction and increase of rotational speed due to the rotor inertia is visible, the controller is capable of altering the operational strategy online and the turbine trajectories smoothly follow the demand. In Fig. 2 (d) the power output of the turbine is shown. The two operational strategies OS1 and OS2 result in approximately the same power production, which in this case was set to demand 70% of the available power (or $p_d = 0.7$). When transitioning from OS1 to OS2, an increase of output power is apparent in a time range from 160 s to approx. 175 s, which stems from the energy released due to the decline in rotational speed being previously stored in the turbine rotation. Consequently, the opposite effect is visible when returning to nominal rotational speed by blending from OS2 to OS1 in the time range of 195 s to 210 s.

180 4.1 Loading in turbulent wind

To compare the structural loading, the turbine was simulated in a turbulent wind field for 40 min at different power setpoints, where an exemplary operating trajectory is shown in Fig. 3 comparing OS1 to OS2. The wind time series was synthesized using TurbSim (Jonkman and Buhl, 2006) and configuring a normal turbulence model at a mean wind speed of 12 m/s. Different 185 constant power demand settings $p_d = \{1, 0.9, 0.8, 0.7, 0.6\}$ are chosen to emulate varying levels of power storage that can be released into the electrical grid by a variation of the power demand (and the opposite way). This flexibility for a reaction to changes in the electrical grid comes at the expense of a reduced energy yield depending on the level of power output reduction.




Figure 3. (a) Wind turbine rotational speed, (b) generator torque and (c) turbine power output in turbulent wind for OS1 and OS2 at 70% of power production, where additionally a 15 s ramp transition at 160 s from OS1 to OS2 and back at 195 s is shown. (c) 40 min power output time series in both operational strategies at 70% power production.




Figure 4. Comparison of damage equivalent turbine loads (DEL) for OS1 and OS2 at different constant power tracking setpoints $p_d = \{1, 0.9, 0.8, 0.7, 0.6\}$, where the data is normalized to the results of $p_d = 1$ in OS1. The data is obtained from operation of the turbine in turbulent wind for 40 minutes with a mean wind speed of 12 m/s, where the simulated wind turbine trajectories for $p_d = 0.7$ are shown in Fig. 3.

In Fig. 4, the resulting damage equivalent loads (DELs) of different turbine components are visualized. All the DELs are normalized to the result when operating the turbine in strategy OS1 at $p_d = 1$, i.e., in nominal operation aiming for maximization of the energy yield. As designed, for $p_d = 1$, the turbine behaves identical for both strategies, which is reflected by the 190 identical loading experienced.

For a power reduction at $p_d = 0.9$, OS1 results in a greater tower loading for both, tower fore-aft (TwrBsMyt) and tower 195 side-to-side (TwrBsMxt) compared to OS2. Contrarily, at higher levels of power reduction, i.e., $p_d = \{0.6, 0.7, 0.8\}$, OS1 shows smaller fatigue loading of the tower compared to OS2. The blade loading is slightly reduced in OS2 compared to OS1 as represented by the out-of-plane torque (RootMyb1) and in-plane torque (RootMxb1). Further, it is observed that the loading 200 caused by the difference torque acting on the low-speed drivetrain shaft (Δ Torque) is reduced in OS1 compared to OS2 at small power derating values (i.e., $p_d = 0.9, 0.8$), while OS2 shows a reduced loading compared to OS1 at higher derating. The pitch activity is greatly affected by the employed operational concept, as can be seen by the increase in actuator duty cycle (ADC) (Riboldi, 2016), where OS1 shows a significantly smaller pitching activity compared to OS2.

Discussion: Loading in turbulent wind

Surprisingly, the fatigue loading of the tower is not reduced in OS2 compared to OS1, despite of the fewer blade-tower 205 interactions due to the reduced rotational speed, as can be seen in Fig. 4. The simulation results suggest that the greater pitch magnitudes (see also the ADC in Fig. 4) for reacting to the varying wind speed in OS2 compared to OS1, along with the strong coupling of the tower to the pitch movement (Bossanyi, 2003), is responsible for this effect. Additionally, in OS2 the 210 turbine operates at smaller rotational speed, and consequently, the 3P excitation of tower due to the rotation is closer to the eigenfrequency of the tower movement. This is supported by the increasing relative tower loading with growing power reduction commands, where in OS2 the rotational speed becomes smaller and thus an increasing loading in the tower, especially 215 in the side-to-side movement, is visible. Opposed to the results discussed in (Jeong et al., 2014; Aho et al., 2016; Lio et al., 2018), OS2 shows increased loading of the tower structure compared to OS1. Additionally for OS1, increasing power reduction commands result in a decreased loading as also found in (Aho et al., 2013; Aho et al., 2016). The greater pitch magnitudes 220 needed for balancing the rotational speed to the desired value are visible in the increased ADC for OS2 compared to OS1 shown in Fig. 4, which is supported by the findings in (Aho et al., 2016; Lio et al., 2018). The pitching activity decreases for greater power reduction in OS1 as also observed in (Aho et al., 2013), while for OS2 the pitch activity increases with increasing power reduction commands. The blade loading is positively affected when operated at a lower rotational speed in OS2 as also 225 reported in (Aho et al., 2013; Aho et al., 2016), especially in flapwise direction. The increased drivetrain loading represented by Δ Torque shown in Fig. 4 in OS2 compared to OS1 especially at small power reduction is also observed in (Aho et al., 2016), but is opposed to the results presented in (Jeong et al., 2014; Lio et al., 2018).

While we have designed a basic controller that only operates based on the rotational speed and pitch angle measurement as 230 shown in (Pöschke et al., 2022), the resulting load profiles may be influenced by the introduction of additional performance shaping control architectures. To achieve this, additional degrees of freedom may be introduced into the modeling and control 235 design process, yielding feedback loops actively shaping the closed-loop dynamics of components like the drivetrain or the

225 tower movement, as discussed in e.g., (Bossanyi, 2003) or specifically for the applied disturbance observer-based approach used here in (Pöschke et al., 2020). From this perspective, the discussed results within this work constitute a fundamental confrontation of operational strategies without any further load reducing loops. This is supported by the control approach yielding similar closed-loop disturbance rejection dynamics for both operational strategies by an identical definition of performance constraints formulated in the model-based design process, which results in the similar evolution of the power output that can be seen in Fig. 3 (e).

4.2 Power tracking dynamics

230 To provide flexible, fast, and predictable control authority to grid stabilizing services and the control loops therein, the response characteristics to changes in the power demand are crucial. To assess the dynamics involved, the turbine is faced with instantaneous demand changes while operating in different constant wind conditions at a constant power output of $p_d = 0.7$ prior to the event. The stepwise changes in the power demand $p_d = 0.7 + \Delta p_d$ are bidirectional, i.e., increase and reduction of the power output demand at steps of Δp is simulated. The applied steps are defined as

$$\Delta p_d = \begin{cases} 0 & \text{if } t \leq 60\text{s} \\ \{-0.3, -0.2, -0.1, 0.1, 0.2, 0.3\} & \text{otherwise} \end{cases} \quad (6)$$

235 The simulation is repeated for wind speeds of $v = \{8, 12, 16\}$ m/s roughly covering a range of common operating wind speeds, and in conjunction with the bidirectional steps possibly reveal nonlinear effects. The resulting step responses of the turbine power for operational strategies OS1 and OS2 are depicted in Fig. 6 (a) and (b), respectively. The results therein are normalized to the demanded magnitude for all steps and power production before the event (effectively to result in comparable steps from 0 to 1 or -1).

240 Fig. 4 (a) shows that the power output of the turbine precisely follows the demand and is immediately adjusted to the new operating point when operating the turbine in OS1, where only the generator torque and pitch angle are varied enforcing a constant rotational speed. This holds for both, an increase and decrease of the power demand equally.

245 In contrast, for OS2 the power output depends on the current operating condition and form of the demand. For a sudden decrease of the power, a settling time of approx. 4 s can be uniformly observed irrespective of the demanded magnitude and current wind speed. However, for an increase in power demand, the power output trajectory is determined by the current inflow conditions. At higher wind speeds, the power output shows similar operating trajectories and settling times as seen at a power decrease. At lower wind speeds, the settling time rises significantly and also shows a decline at the beginning of the demand step or closely afterwards as can be observed in the trajectories that have not settled to the demanded value at a time of 75 s.

250 The different operating strategies yield varying amounts of ultimate loading depending on the considered structural turbine component, wind speed and magnitude of the power demand step, which is shown in Fig. 5. The greatest absolute increase in ultimate loading for all considered components is found at a wind speed of 12 m/s, which is an information shadowed due to the normalization in Fig. 5. The simulation data shows that the magnitude of power demand step dictates the additional ultimate loading experienced by the turbine as the ultimate loading is smaller for steps of $\Delta p_d = \{-0.1, 0.1\}$. Additionally,




Figure 5. Comparison of normalized ultimate loads for stepwise variation of power demand $\Delta p_d = \{-0.3, -0.2, -0.1, 0.1, 0.2, 0.3\}$ operated in different constant winds. The results are normalized to the ultimate load occurring for a step of $\Delta p_d = -0.3$ in OS1 for each of the considered ultimate load and wind.

a tendency for smaller ultimate loading for a reduction of the power output ($\Delta p_d < 0$) compared to the stepwise increase in power is visible. OS1 is superior compared to strategy OS2 in avoiding additional ultimate loading due to the variation of power output especially at greater wind speeds (12 m/s and 16 m/s). Contrarily, significant differences in ultimate loading are also found when an increase of power is demanded ($\Delta p_d = \{0.3, 0.2\}$) at low wind speeds, where OS2 shows to be superior to OS1.

Discussion & modeling: Power tracking dynamics

The results reveal the dependency of the response characteristic on the employed operational strategy. For OS1, very fast responses to the step demand are possible. This aligns with (Jeong et al., 2014; Aho et al., 2016), where an increased power tracking performance is found when keeping the rotational speed constant and varying the power with the torque only. The response illustrated in Fig. 4 (b) reveals a first-order dynamic behavior in OS1 that can be accounted to the generator torque dynamics used in the simulation model. It is observed that the first-order dynamics is present irrespective of the current wind speed, step magnitude, or direction of step. In the frequency domain, this transfer function can be given as

$$265 \quad G_{OS1}(s) = \frac{1}{T_{OS1}s + 1} \quad (7)$$

with timescale T_{OS1} governed by the generator torque loop. The transfer function $G_{OS1}(s)$ is found sufficient for describing the power demand dynamics of the wind turbine if a strategy like (or very similar to) OS1 is chosen by the turbine control engineer. The step response of the transfer function with $T_{OS1} = 20$ ms is shown in Fig. 6 (a).

If, however, acceleration and deceleration of the turbine is involved in meeting the desired power demand as defined for OS2, the attainable power dynamics depends on the current operating point and direction of the step demand as illustrated in Fig. 5 (c). As a result, an adequate model of the active power dynamics for this strategy depends on the current operating point and step magnitude, revealing the nonlinearities inherited in the system. From Fig. 6 it can be observed that especially an increase in




Figure 6. Normalized step response for demand steps of $\Delta p_d = \{-0.3, -0.2, -0.1, 0.1, 0.2, 0.3\}$ when operating the turbine at a power reserve with $p_d = 0.7$ in constant wind for (a) in OS1 and (b) in OS2. Comparison of step response to the synthetic transfer functions $G_{OS1/OS2}(s)$ designed for control design and simulation studies on a power system or wind farm level.

power, i.e., $\Delta p_d > 0$ results in varying response dynamics due to the varying levels of excess power when increasing the power demand¹. Further, it can be observed that the resulting power dynamics is governed by the applied control scheme, which is

275 the cause for the non-minimum phase behavior seen at some operating trajectories. This behavior is observed when operating the turbine in partial-load region (i.e., in the simulated cases for a wind speed of $v = 8 \text{ m/s}$), where the generator torque is employed to control the rotational speed. When the power command increases, the altered rotational speed setpoint results in a reduction of the generator torque by the controller to allow turbine acceleration. This effect necessitates an extension of the transfer function assigned to OS1 to account for this kind of non-minimum phase behavior that usually is also an important

280 aspect in the modeling of hydro-power for grid studies and control design (Kishor et al., 2007; Björk et al., 2021).

Following the conception of OS2, the response characteristic is governed by two processes consisting of generator torque actuation in parallel to a variation of the rotational speed. The rotation is determined by a combination of excess power for (de-)acceleration and the wind turbine inertia. Following this reasoning, a simple transfer function for OS2 consisting of two parallel paths described as

$$G_{OS2}(s) = G_I(s) + G_{II}(s)$$

285 with $G_{I/II}(s) = k_{I/II} \frac{a_{I/II}s + b_{I/II}}{c_{I/II}s + d_{I/II}}$ (8)

¹As the command is normalized to the currently available power, the same magnitude of Δp_d results in different power levels usable for an acceleration of the turbine depending on the wind speed.

shows to provide a reasonable match to the simulated turbine step response, see Fig. 6 (b). As the dynamics vary with the wind speed, the transfer function displaying the power dynamics in OS2 needs re-parametrization depending on the current operating point, i.e., the parameters are functions of the wind speed $k/a/b/c/d_{I/II} = f(v)$. The parameters of the "upper" and "lower" bound (for the considered scenarios in Fig. 6 (b)) in $G_{OS2}(s)$ are displayed in Tab. 1. While the number of ten parameters 290 might seem complex to parametrize, the two configurations follow a physically interpretable rationale as follows.

Table 1. Values of the transfer functions used for upper and lower bound parametrization in OS2

Parameter	k_I	a_I	b_I	c_I	d_I	k_{II}	a_{II}	b_{II}	c_{II}	d_{II}
Upper bound	0.5	0	1	1.25	1	0.5	0	1	0.02	1
Lower bound	1	0	1	10	1	-1	0.5	0	1	0.05

The upper bound parametrization corresponds to the highest simulated wind speed of $v = 16$ m/s and consists of two parallel first-order functions, i.e., $G_{I/II}(s) = k_{I/II} \frac{1}{c_{I/II}s + 1}$. The two parallel processes consist of torque and rotational speed setpoint variation, and therefore, $c_{I/II}$ describe the dynamics of closed-loop torque and inertia-based rotational speed evolution, respectively. As the concept in OS2 relies on an equal setpoint sharing among torque and rotational speed (established by $\sqrt{p_d}$ in (2)), 295 setting $k_{I/II} = 0.5$ is an intuitive choice. On the other hand, in the lower bound parametrization corresponding to partial-load operation at $v = 8$ m/s, the discussed controller interaction from the rotational speed to the torque actuation plays a dominant role and decays when the desired rotational speed is reached. Therefore, the two parallel process are I: the torque actuated rotation as first-order transfer function $G_I = \frac{1}{c_I s + 1}$ and II: a negative derivative transfer function $G_{II} = -\frac{a_{II}s}{s + d_{II}}$. The influence 300 of $G_{II}(s)$ vanishes as $s \rightarrow 0$ to account for the non-minimum phase behavior stemming from the control interaction. Note that c_I represents the inertia in combination with the available power in both upper and lower bound, but due to the varying power levels substantially depend on the current wind speed, see the parameters in Tab. 1.

From consideration of the ultimate loading, it was found that OS1 by remaining at constant rotational speeds tends to be superior to OS2 in avoiding additional ultimate loading of the components. As concluded for fatigue loading in turbulent wind, the lower pitch magnitudes needed in OS1 compared to OS2 cause smaller excitation of the turbine structure, and consequently 305 result in lower or similar ultimate loading when instantaneously adjusting the current power demand. At the lower wind speed (8 m/s) and a power increase of $\Delta p_d = \{0.2, 0.3\}$, OS2 significantly outperformed OS1 in ultimate loading, especially for the tower. Those scenarios, however, showed unsatisfactory response dynamics to the power changes in OS2, as discussed for the power output trajectories in Fig. 6 (b). The comparatively low power that is solely available for an acceleration of the turbine has positive effects on the ultimate loading experienced by the turbine in these cases.

310 5 Conclusion

Within this contribution, it is discussed how different operational strategies for wind turbines can be integrated into a model-based control design by choice of the linearization points. The influence on the attainable power dynamics for supporting the

electrical grid and the resulting loading are analyzed for synthetically designed scenarios. The presented simulation studies reveal the dependency of the power dynamics on the operational strategy. It is found that OS1 (keeping the rotational speed 315 constant) provides significantly faster control authority in the power dynamics compared to OS2, where a deceleration or acceleration of the turbine's rotor is performed. This result is supported by the findings in (Jeong et al., 2014; Aho et al., 2016). While for OS1 the fast generator dynamics are governing, the response in OS2 is mainly determined by the turbine's inertia. This underlines the additional flexibility in following a power demand in favor of the electrical grid when using OS1, where the amount of injected power can be controlled by the generator torque at a fast scale.

320 While faster power dynamics in OS1 could be expected, the results from a loading perspective are surprising, which holds for both, the fatigue loading during turbulent wind and the ultimate loading at power demand steps. Except for the lower blade out-of-plane loading in OS2, it was found that OS1 in the considered turbulent wind scenario and turbine setup showed smaller fatigue loading of the tower despite the greater rotational speed. OS1 also tends to decrease the ultimate loads when following a power demand step compared to OS2. In general, it is found that a reduced power output operating point results in reduced 325 turbine loading.

330 While the presented results suggest an application of OS1 from both considered perspectives, i.e., loading and power dynamics, the considered scenarios within this work are limited, where a variety of different aspects can determine the choice of the operational strategy applied to the turbine (also e.g., bird fatalities (Baerwald et al., 2009) or noise emission (Leloudas et al., 2007) decrease with lower rotational speed). Additionally, as shown in (Zhu et al., 2017; Lio et al., 2018), operating the turbine 340 at lower rotational speeds decreases the thrust coefficient of the turbine, and thus possibly mitigates the wake induced effects for downstream turbines in OS2 compared to OS1. [For the application of dynamic induction control, \(Munters and Meyers, 2018; Frederik et al., 2020\) concluded that the Strouhal number can be used to obtain the variation frequency and a value of 0.25 is identified as favorable. For the considered turbine here this results in operating point changes with a period time of 62 s. As some operating trajectories in OS2 showed settling times above 15 s, the impact on the effectiveness of the dynamic induction approach has to be evaluated.](#) For OS1, however, the fast power tracking in the time scale of the generator dynamics 345 indicates sufficient response characteristics for many applications. In this study, it is demonstrated how a dedicated control design allows for an online variation of the operational strategy, such that wind turbines can flexibly adjust the operational strategy subject to varying external demands.

350 For studying stability of the power system with a high share of decentralized generation, the participating power units and their relevant dynamical behavior must be considered and combined with models of the electrical grid. Therefore, modeling approaches are needed capable of portraying relevant dynamical properties, while satisfying complexity constraints to be suitable for the large-scale integration in both advanced control design on a power system level, and the required simulations studies. The results obtained from the simulation studies suggest that the model for portraying the relevant dynamics depends on the chosen operating strategy. When aiming for constant rotational speed in a reduced power mode, a first-order transfer 355 function governed by the closed-loop generator dynamics is seen to provide a reasonable model description. If a simultaneous rotational speed variation is assigned in the control scheme, the inertial response of the turbine rotor in conjunction with the available excess power needs to be considered in the description. Due to the nonlinearities in the energy conversion process

and the control interaction, the model for this operational strategy necessarily comprises varying parameters depending on the considered operating point.

350 *Code and data availability.* For inquiries about the source code and data, please reach out the corresponding author.

Author contributions. Florian Pöschke (FP) and Horst Schulte (HS) conceptualized the study and operating trajectories. FP conducted the control design and simulation studies. FP and HS analyzed the results, drew conclusions and created the manuscript.

Competing interests. The authors declare that they have no conflict of interest.

Acknowledgements. This project has received funding from the European Union’s Horizon 2020 research and innovation programme under 355 grant agreement No. 883985 (POSYTYF – POwering SYstem flexibiliTY in the Future through RES). <https://posytf-h2020.eu/>

References

Abouzeid, S. I., Guo, Y., and Zhang, H.-C.: Dynamic control strategy for the participation of variable speed wind turbine generators in primary frequency regulation, *Journal of Renewable and Sustainable Energy*, 11, 013 304, <https://doi.org/10.1063/1.5064846>, 2019.

Aho, J., Pao, L., and Fleming, P.: An Active Power Control System for Wind Turbines Capable of Primary and Secondary Frequency Control for Supporting Grid Reliability, in: 51st AIAA Aerospace Sciences Meeting including the New Horizons Forum and Aerospace Exposition, <https://doi.org/10.2514/6.2013-456>, 2013.

Aho, J., Fleming, P., and Pao, L. Y.: Active power control of wind turbines for ancillary services: A comparison of pitch and torque control methodologies, in: 2016 American Control Conference (ACC), pp. 1407–1412, <https://doi.org/10.1109/ACC.2016.7525114>, 2016.

Baerwald, E. F., Edworthy, J., Holder, M., and Barclay, R. M. R.: A large-scale mitigation experiment to reduce bat fatalities at wind energy facilities, *The Journal of Wildlife Management*, dOI: 10.2193/2008-233, 2009.

Björk, J., Johansson, K. H., and Dörfler, F.: Dynamic Virtual Power Plant Design for Fast Frequency Reserves: Coordinating Hydro and Wind, 2021.

Boersma, S., Doekemeijer, B., Gebraad, P., Fleming, P., Annoni, J., Scholbrock, A., Frederik, J., and van Wingerden, J.-W.: A tutorial on control-oriented modeling and control of wind farms, in: 2017 American Control Conference (ACC), pp. 1–18, <https://doi.org/10.23919/ACC.2017.7962923>, 2017.

Bossanyi, E. A.: Wind turbine control for load reduction, *Wind Energy*, 6, <https://doi.org/10.1002/we.95>, 2003.

Boyd, S., Ghaoui, L. E., Feron, E., and Balakrishnan, V.: *Linear Matrix Inequalities in System and Control Theory*, Society for Industrial and Applied Mathematics, <https://doi.org/10.1137/1.9781611970777>, 1994.

Campagnolo, F., Petrović, V., Bottasso, C. L., and Croce, A.: Wind tunnel testing of wake control strategies, in: 2016 American Control Conference (ACC), pp. 513–518, <https://doi.org/10.1109/ACC.2016.7524965>, 2016.

Chilali, M. and Gahinet, P.: H_∞ design with pole placement constraints: an LMI approach, *IEEE Transactions on Automatic Control*, 41, 358–367, <https://doi.org/10.1109/9.486637>, 1996.

Deshpande, A. S. and Peters, R. R.: Wind turbine controller design considerations for improved wind farm level curtailment tracking, in: 2012 IEEE Power and Energy Society General Meeting, pp. 1–6, <https://doi.org/10.1109/PESGM.2012.6343975>, 2012.

Frederik, J. A., Weber, R., Cacciola, S., Campagnolo, F., Croce, A., Bottasso, C., and van Wingerden, J.-W.: Periodic dynamic induction control of wind farms: proving the potential in simulations and wind tunnel experiments, *Wind Energy Science*, 5, 245–257, <https://doi.org/10.5194/wes-5-245-2020>, 2020.

Galinos, C., Urbán, A. M., and Lio, W. H.: Optimised de-rated wind turbine response and loading through extended controller gain-scheduling, *Journal of Physics: Conference Series*, 1222, 012 020, <https://doi.org/10.1088/1742-6596/1222/1/012020>, 2019.

Goit, J. P. and Meyers, J.: Optimal control of energy extraction in wind-farm boundary layers, *Journal of Fluid Mechanics*, 768, 5–50, <https://doi.org/10.1017/jfm.2015.70>, 2015.

Inthamoussou, F. A., De Battista, H., and Mantz, R. J.: LPV-based active power control of wind turbines covering the complete wind speed range, *Renewable Energy*, 99, 996–1007, <https://doi.org/10.1016/j.renene.2016.07.064>, 2016.

Jain, A., Sakamuri, J. N., and Cutululis, N. A.: Grid-forming control strategies for black start by offshore wind power plants, *Wind Energy Science*, 5, 1297–1313, <https://doi.org/10.5194/wes-5-1297-2020>, 2020.

Jeong, Y., Johnson, K., and Fleming, P.: Comparison and testing of power reserve control strategies for grid-connected wind turbines, *Wind Energy*, 17, 343–358, <https://doi.org/10.1002/we.1578>, 2014.

Jonkman, J. M. and Buhl, M. L.: FAST Users Guide, Tech. rep., National Renewable Energy Laboratory, 2005.

Jonkman, J. M. and Buhl, M. L.: TurbSim User's Guide, Tech. rep., National Renewable Energy Laboratory, 2006.

395 Jonkman, J. M. and Jonkman, B. J.: FAST modularization framework for wind turbine simulation: full-system linearization, *Journal of Physics: Conference Series*, 753, 082010, <https://doi.org/10.1088/1742-6596/753/8/082010>, 2016.

Jonkman, J. M., Butterfield, S., Musial, W., and Scott, G.: Definition of a 5-MW Reference Wind Turbine for Offshore System Development, Tech. rep., National Renewable Energy Laboratory, 2009.

Kanev, S., Savenije, F., and Engels, W.: Active wake control: An approach to optimize the lifetime operation of wind farms, *Wind Energy*, 400 21, 488–501, <https://doi.org/https://doi.org/10.1002/we.2173>, 2018.

Kazda, J., Merz, K., Tande, J. O., and Cutululis, N. A.: Mitigating turbine mechanical loads using engineering model predictive wind farm controller, *Journal of Physics: Conference Series*, 1104, <https://doi.org/10.1088/1742-6596/1104/1/012036>, 2018.

Kishor, N., Saini, R., and Singh, S.: A review on hydropower plant models and control, *Renewable and Sustainable Energy Reviews*, 11, 776–796, <https://doi.org/https://doi.org/10.1016/j.rser.2005.06.003>, 2007.

405 Leloudas, G., Zhu, W. J., Sørensen, J. N., Shen, W. Z., and Hjort, S.: Prediction and Reduction of Noise from a 2.3 MW Wind Turbine, *Journal of Physics: Conference Series*, 75, 012083, <https://doi.org/10.1088/1742-6596/75/1/012083>, 2007.

Lio, W. H., Mirzaei, M., and Larsen, G. C.: On wind turbine down-regulation control strategies and rotor speed set-point, *Journal of Physics: Conference Series*, 1037, 032040, <https://doi.org/10.1088/1742-6596/1037/3/032040>, 2018.

Machowski, J., Bialek, J., and Bumby, J.: *Power System Dynamics: Stability and Control*, John Wiley & Sons, Ltd, 2008.

410 Margaritis, I. D., Papathanassiou, S. A., Hatziargyriou, N. D., Hansen, A. D., and Sorensen, P.: Frequency Control in Autonomous Power Systems With High Wind Power Penetration, *IEEE Transactions on Sustainable Energy*, 3, 189–199, <https://doi.org/10.1109/TSTE.2011.2174660>, 2012.

Mirzaei, M., Soltani, M., Poulsen, N. K., and Niemann, H. H.: Model based active power control of a wind turbine, in: 2014 American Control Conference, pp. 5037–5042, <https://doi.org/10.1109/ACC.2014.6859055>, 2014.

415 Munters, W. and Meyers, J.: Towards practical dynamic induction control of wind farms: analysis of optimally controlled wind-farm boundary layers and sinusoidal induction control of first-row turbines, *Wind Energy Science*, 3, 409–425, <https://doi.org/10.5194/wes-3-409-2018>, 2018.

Petrović, V. and Bottasso, C. L.: Wind turbine envelope protection control over the full wind speed range, *Renewable Energy*, 111, 836 – 848, <https://doi.org/10.1016/j.renene.2017.04.021>, 2017.

420 Pöschke, F., Gauterin, E., Kühn, M., Fortmann, J., and Schulte, H.: Load mitigation and power tracking capability for wind turbines using linear matrix inequality-based control design, *Wind Energy*, 23, 1792–1809, <https://doi.org/10.1002/we.2516>, 2020.

Pöschke, F., Petrović, V., Berger, F., Neuhaus, L., Hölling, M., Kühn, M., and Schulte, H.: Model-based wind turbine control design with power tracking capability: A wind-tunnel validation, *Control Engineering Practice*, 120, 105014, <https://doi.org/10.1016/j.conengprac.2021.105014>, 2022.

425 Rebello, E., Watson, D., and Rodgers, M.: Ancillary services from wind turbines: automatic generation control (AGC) from a single Type 4 turbine, *Wind Energy Science*, 5, 225–236, <https://doi.org/10.5194/wes-5-225-2020>, 2020.

Riboldi, C. E.: On the optimal tuning of individual pitch control for horizontal-axis wind turbines, *Wind Engineering*, 40, 398–416, <https://doi.org/10.1177/0309524X16651545>, 2016.

Shan, M., Shan, W., Welck, F., and Duckwitz, D.: Design and laboratory test of black-start control mode for wind turbines, *Wind Energy*, 23, 430 763–778, <https://doi.org/10.1002/we.2457>, 2020.

435 Vali, M., Petrović, V., Steinfeld, G., Y. Pao, L., and Kühn, M.: An active power control approach for wake-induced load alleviation in a fully developed wind farm boundary layer, *Wind Energy Science*, 4, 139–161, <https://doi.org/10.5194/wes-4-139-2019>, 2019.

Van de Vyver, J., De Kooning, J. D. M., Meersman, B., Vandeveld, L., and Vandoren, T. L.: Droop Control as an Alternative Inertial Response Strategy for the Synthetic Inertia on Wind Turbines, *IEEE Transactions on Power Systems*, 31, 1129–1138, <https://doi.org/10.1109/TPWRS.2015.2417758>, 2016.

436 van der Hoek, D., Kanev, S., Allin, J., Bieniek, D., and Mittelmeier, N.: Effects of axial induction control on wind farm energy production - A field test, *Renewable Energy*, 140, 994–1003, <https://doi.org/https://doi.org/10.1016/j.renene.2019.03.117>, 2019.

437 van der Hoek, D., Frederik, J., Huang, M., Scarano, F., Simao Ferreira, C., and van Wingerden, J.-W.: Experimental analysis of the effect of dynamic induction control on a wind turbine wake, *Wind Energy Science*, 7, 1305–1320, <https://doi.org/10.5194/wes-7-1305-2022>, 2022.

440 van Kuik, G. A. M., Peinke, J., Nijssen, R., Lekou, D., Mann, J., Sørensen, J. N., Ferreira, C., van Wingerden, J. W., Schlipf, D., Gebraad, P., Polinder, H., Abrahamsen, A., van Bussel, G. J. W., Sørensen, J. D., Tavner, P., Bottasso, C. L., Muskulus, M., Matha, D., Lindeboom, H. J., Degraer, S., Kramer, O., Lehnhoff, S., Sonnenschein, M., Sørensen, P. E., Künneke, R. W., Morthorst, P. E., and Skytte, K.: Long-term research challenges in wind energy – a research agenda by the European Academy of Wind Energy, *Wind Energy Science*, 1, 1–39, <https://doi.org/10.5194/wes-1-1-2016>, 2016.

445 VanAntwerp, J. G. and Braatz, R. D.: A tutorial on linear and bilinear matrix inequalities, *Journal of Process Control*, 10, 363–385, [https://doi.org/10.1016/S0959-1524\(99\)00056-6](https://doi.org/10.1016/S0959-1524(99)00056-6), 2000.

Xin, H., Gan, D., Li, N., Li, H., and Dai, C.: Virtual power plant-based distributed control strategy for multiple distributed generators, *IET Control Theory & Applications*, 7, 90–98(8), <https://digital-library.theiet.org/content/journals/10.1049/iet-cta.2012.0141>, 2013.

450 Zhu, J., Ma, K., Soltani, M., Hajizadeh, A., and Chen, Z.: Comparison of loads for wind turbine down-regulation strategies, in: 2017 11th Asian Control Conference (ASCC), pp. 2784–2789, <https://doi.org/10.1109/ASCC.2017.8287618>, 2017.