



Estimating Long-Term Annual Energy Production of a Large Offshore Wind Farm from Large-Eddy Simulations: Methods and Validation with a 10-Year Simulation

Bernard Postema¹, Remco Verzijlbergh^{1,2}, Pim Van Dorp¹, Peter Baas¹, and Harm Jonker^{1,3}

¹Whiffle BV, Molengraaffsingel 8, 2629 JD Delft, the Netherlands

²Department of Engineering Systems and Services, Delft University of Technology, Jaffalaan 5, 2628 BX Delft, the Netherlands

³Department of Geoscience and Remote Sensing, Delft University of Technology, Stevinweg 1, 2628 CN Delft, the Netherlands

Correspondence: Bernard Postema (bernard.postema@whiffle.nl)

Abstract.

Atmospheric large-eddy simulation (LES), a computational fluid-dynamics technique that resolves turbulence in the atmospheric boundary layer, is increasingly used for wind resource assessment (WRA), by including wind turbine parametrizations and using external weather data as initial- and boundary conditions. The large computational costs of doing such a 'real-weather' LES, however, limits length of the simulation to ≤ 1 year; whereas long-term, multi-year, mean power production values are of high interest to many parties in the wind energy sector. To address this need, this work presents several methods to estimate long-term mean power production/annual energy production and wind from a ≤ 1 year LES run, by applying Bayes' theorem on short-term LES output and long-term ERA5 reanalysis data.

A 10-year LES run of a hypothetical large offshore wind farm is performed in order to validate these 'long-term correction' methods, in three scenarios of increasing complexity. First, long-term correction of 365 consecutive days gives estimates of long-term mean power with a mean absolute error of 0.35 %, and 95th percentile of the absolute error within 0.8 % of the long-term mean, reducing the uncertainty by an order or magnitude. Second, in the scenario when the simulation period is not fixed, using several day selection techniques to select the simulation period can reduce the error further. Then, only around 200 days are needed to arrive at the same error values. The results indicate that long-term correction is insensitive to the particulars of the day selection methods, but that including a diverse set of days from different years and seasons is essential. Third, a method to also include wind observations in the long-term correction is presented and tested. This requires an additional 'free stream' LES run without active turbines, and gives estimates of long-term power and wind that are corrected for a potential LES bias. Although validation of this final approach is difficult in the employed modelling strategy, it gives valuable insights, and fits within the common WRA practice of combining models and observations.

The presented techniques are based on physical arguments, computationally cheap, and simple to implement; and as such could be a useful extension to the diverse set of modelling, observational, and statistical techniques used in WRA.



1 Introduction

Among the diverse set of tools used for wind resource assessment (WRA), one class of very fine-scale models is large-eddy simulation (LES), which' resolution of about 10 m to 100 m allows explicit simulation of the most energetic part of the turbulence in the atmospheric boundary layer. Before its application in WRA, LES has traditionally been applied to research fundamental meteorological processes, such as dry and moist convection, clouds, stratification, and dispersion (Stoll et al., 2020). To simulate atmospheric flow with an LES, realistic boundary- and initial conditions need to be prescribed, which can be taken from a coarser (global) weather model, or from reanalysis data (historical atmospheric data). This so called 'real-weather' LES has been demonstrated to be viable (Schalkwijk et al., 2015; van Stratum et al., 2023), and can be used to study atmospheric flow, but also to explicitly model the interactions between wind farms and the atmosphere (Baas et al., 2023). This latter application provides many opportunities in the field of WRA because an LES explicitly resolves important effects such individual turbine- and park wakes, global blockage, and atmospheric stability.

LES of flow around and through wind parks provides insight into the dynamics that govern the park's power production, and can be used to investigate different types (internal, external) of wake losses. For this purpose, the current state of the art is to simulate one year, which comprises 365 consecutive days (e.g. the year of 2023), in order to provide an overlap with observation data, which are often only available during roughly one year. The simulation then includes the most important effects of weather conditions on wind park power production; on the turbulent, to the synoptic, to the seasonal timescale. This approach, however, means that any inter-annual variability is not taken into account. This is a major shortcoming, because the multi-year ($O(10\text{ y})$) projected power production is of high interest to many parties involved in wind energy development, and interannual variability is significant (about 4 % of the long-term mean (Pryor et al., 2018)). One solution to this is to run computationally less expensive wake models (Göçmen et al., 2016) for a large range of flow cases, and then to integrate the power productions weighted by each flow case's occurrence frequency (Laan et al., 2022; Locascio et al., 2022, their eqn. 1), requiring probability distributions of wind speed and -direction (a wind rose). Alternatively, for instance if there are no observation data, one could apply a method of selecting simulation days that together are representative of the long-term climate (Rife et al., 2013), and then run these with a high-fidelity model. Both these approaches have their merits, but forego either the benefit of the detailed physics in real-weather LES for WRA, or its possibility to compare the model output to observations. Methods to accurately estimate long-term average power production without resorting to either a computationally cheaper model of lower physical fidelity, or a longer but too expensive LES run, would therefore be very useful in the WRA field.

To address this need, this work presents several methods to correct the power production and other (meteorological) variables as estimated by a short $\leq 1\text{ y}$ LES run of a large offshore wind farm for interannual variability and/or bias with respect to observations, thus giving an estimate of the long-term (climatological) value of those variables. These hereby called 'long-term correction' methods are based on the fundamental statistical theorem of Bayes, and estimate the long-term probability density of an LES variable, given *i*) the short-term joint probability density between the said LES variable and a reference variable in the reanalysis data, and *ii*) the long-term probability density of the reference variable in the reanalysis data. The presence or absence of observation data suggest the following three scenarios in which long-term correction can typically be applied:



1. LES wind farm power output of a predetermined set of 365 consecutive days is available, and needs to be corrected for interannual variability, but not for a bias with respect to observations.
2. The LES run period can be freely chosen, because there are no observations that need to be concurrent. The run period can therefore be a smartly chosen (representative) selection of days, which, after applying the long-term correction method, yields the best estimate of the long-term mean wind farm power.
3. LES wind farm power output of a predetermined set of 365 consecutive days is available. The power output needs to be long-term corrected for interannual variability and simultaneously be corrected for the bias with respect to observations.

In this study, 10 years of weather conditions and atmospheric flow through a large (960 MW) hypothetical wind farm on the North Sea are simulated with an LES, in order to validate the long-term correction methods in the three typical situations listed above. There is a long record of undisturbed observations in the location of the hypothetical wind farm, allowing validation of the LES, and testing the method of bias correction. The employed LES code is the Atmospheric Simulation Platform for Innovation, Research, and Education (ASPIRE). ASPIRE has its origins in the Dutch Atmospheric Large Eddy Simulation (DALES) model (Heus et al., 2010), but has since been ported to Graphics Processing Units (Schalkwijk et al., 2012, 2015), and is currently used for research as well as commercial purposes, mainly in the wind energy sector (Gilbert et al., 2020; Verzijlbergh, 2021; Kantharaju et al., 2023; Bieringer et al., 2021).

The present work focuses on the performance of the long-term correction methods given the employed model setup: validation of the wind farm modelling itself is not part of the scope. The paper is structured as follows: Sect. 2 gives the theory behind the long-term correction methods, Sect. 3 describes the LES setup, methods of wind farm modelling, observation data, and day selection techniques. Then, results and discussion will be presented in Sect. 4 following the three scenario's above, and finally conclusions on the application of the long-term correction methods will be drawn in Sect. 5.

2 Theory of long-term correction of LES wind and wind farm power production

The goal of this work is to estimate long-term ($O(10\text{ y})$) mean values of wind farm power production and wind from a much shorter ($O(1\text{ y})$) LES run. The mean values of that shorter run can deviate from their true long-term counterparts for two reasons: *i)* the short LES run has different mean meteorological conditions than the long-term mean (this is normal climatological variability), and *ii)* the LES may display a consistent mean bias with respect to reality (this can be caused by a multitude of model flaws). The first can be corrected with purely atmospheric reanalysis data, such as the ERA5 reanalysis dataset, which is a global historical record of atmospheric conditions (Hersbach et al., 2020), and in this study also provides boundary conditions for the LES. The second also needs on-site observations that are concurrent with the LES run, to quantify the bias. The following two sections explain the long-term correction methods designed to correct these deviations and to arrive at an estimate of the long-term mean power production and wind.



2.1 Long-term correction without observations

An LES run, which can be either a set of consecutive days or a smartly chosen sample (scenarios 1 and 2 in the introduction), provides timeseries of power production of the entire wind farm(P), and, for instance, wind speed at a location in or close to the wind farm (M). These two variables have their probability densities ($f_L(P)$, $g_L(M)$), where the subscript L refers to the

90 LES.

Also, from an external atmospheric reanalysis dataset (in this case ERA5) the wind record during the simulation time can be taken, which has its own wind distribution $g_{\text{ERA}}(M)$. Furthermore, the *joint* probability densities between LES power and ERA5 wind ($h_{L, \text{ERA}}(P, M)$), and their *conditional* probability densities ($h_{L| \text{ERA}}(P, M)$) can be calculated. The former can be interpreted as a 'two-dimensional probability density', and the latter describes the distribution of the first variable between

95 brackets, given a value of the second.

Now limiting the attention to wind farm power production, Bayes' theorem, one of the fundamentals of statistics, describes the relation between the different distributions:

$$h_{L, \text{ERA}}(P, M) = h_{L| \text{ERA}}(P, M)g_{\text{ERA}}(M). \quad (1)$$

Integrating eqn. 1 over M retrieves $f_L(P)$:

$$100 \quad \int h_{L, \text{ERA}}(P, M)dM = \int h_{L| \text{ERA}}(P, M)g_{\text{ERA}}(M)dM = f_L(P). \quad (2)$$

Denoting long-term, climatological, ($O(10 \text{ y})$) counterparts of the PDFs with hats, eqn. 2 takes on the analogous form for the long-term:

$$\hat{f}_L(P) = \int \hat{h}_{L, \text{ERA}}(P, M)dM = \int \hat{h}_{L| \text{ERA}}(P, M)\hat{g}_{\text{ERA}}(M)dM. \quad (3)$$

If the LES run period is long enough and includes a sufficiently diverse range of weather conditions, it can be assumed that
 105 the conditional probability between power and wind approximates its long-term counterpart:

$$h_{L| \text{ERA}}(P, M) \approx \hat{h}_{L| \text{ERA}}(P, M). \quad (4)$$

Physically, this means assuming that the short simulation accurately captures the range of wind farm power production values that belong to a given wind speed. As will be shown in Sect. 4.1, this range can be significant.

Then, substituting this assumption in eqn. 3 gives an estimate of the long-term distribution of power production:

$$110 \quad \hat{f}_L(P) \approx \int h_{L| \text{ERA}}(P, M)\hat{g}_{\text{ERA}}(M)dM. \quad (5)$$



So, eqn. 5 provides an estimate of the long-term probability distribution of LES power production (or wind, analogously) given *i*) the short-term conditional probability density of LES power (or wind) and reanalysis wind, and *ii*) the long-term probability distribution of the reanalysis wind. The long-term mean power production can then be calculated by taking the first moment of the distribution:

$$\overline{P} = \int f_L(P) P dP, \quad (6)$$

and this mean power value (typically in MW) can be translated to the annual energy production (AEP, typically in GWh) by multiplying with one year.

2.2 Integrating observation data to correct for a model bias

In the practice of LES modelling, it is often found that the wind speed displays a mean bias of $O(0.1 \text{ m s}^{-1})$ with respect to observations (scenario 3). Because observations for WRA are usually done in an undisturbed environment (before construction of the wind farm), a second 'free stream' validation LES run is needed to determine this bias. Such a free stream run has no turbines included, or it has turbines that exert no force on the flow, and therefore leave it undisturbed. Apart from this, the two run setups are identical, allowing for a direct quantification of wake- and blockage losses.

The potential wind bias identified in a free stream run will also be similarly present in the wind farm power production with active turbines, and its long-term corrected counterpart, when applying the methodology of the previous section. To estimate long-term mean power production while also correcting for a bias, therefore, a different approach needs to be taken, which cannot rely on the absolute wind- or power values produced by the LES (because they are biased). Rather, this new approach needs to rely on the statistical relationship between power production of the LES run with active turbines, and the LES wind of a free stream run, i.e. $h_{L|FSL}(P, M)$, where the subscript FSL denotes free stream LES, and the subscript L keeps referring to the run with active turbines. Despite its hypothetical nature (it cannot be measured in any way in reality), this conditional probability is assumed to be accurate, because of the explicit representation of all fluid dynamical and meteorological processes that affect it; such as wakes, blockage, and stability effects (see e.g. Mehta et al., 2014; Breton et al., 2017).

Following again Bayes' theorem, an estimate of the long-term power distribution can then be obtained by integrating the product of $h_{L|FSL}(P, M)$ and the probability distribution of unbiased long-term wind speed. The latter can be obtained from observations combined with reanalysis data. This is done in the form of a Measure-Correlate-Predict (MCP) procedure (a common technique used for WRA, see e.g. Carta et al. (2013)), which (per wind direction bin) fits the reanalysis wind to observation data, and then applies this fit to the long-term reanalysis record, thereby creating a semi-artificial long-term wind record, which has no bias with respect to the observation data from which it was constructed. This long-term MCP wind can therefore be seen as a bias-corrected version of the reanalysis wind. Using the long-term distribution of the MCP wind ($\hat{g}_{MCP}(M)$) together with the conditional probability $h_{L|FSL}(P, M)$ gives the estimate of the long-term power distribution the following form:



$$\hat{f}(P) \approx \int h_{L|FSL}(P, M) \hat{g}_{MCP}(M) dM. \quad (7)$$

where the subscript L on the left hand side has been dropped, because the equation aims to estimate the real long-term power production, not its (possibly biased) long-term LES value. So, eqn. 7 (see the similarity to eqn. 3) provides a way to integrate
 145 observations into the long-term correction of power. An analogous form of eqn. 7 also works for non-free stream wind (wind disturbed by the wind farm, in the run with active turbines), but not for the free stream wind itself, because the integral then reduces to $\hat{g}_{MCP}(M)$.

The integral quantities presented until here are computed as discrete sums when applying long-term correction. This means
 150 the quantities of interest need to be binned in such a way that the crucial assumption $h_{L|ERA}(P, M) \approx \hat{h}_{L|ERA}(P, M)$ holds as well as possible. The implied assumption is that all quantities that influence (either directly or indirectly) the power production (stability, wind direction, air density) also obey this approximation. For wind, bins of 0.75 m s^{-1} are chosen, and sensitivity to this value will be shown. If one is interested in the long-term mean of the variable that is being long-term corrected (in the previous examples power production), bins of that variable can be arbitrarily small. This is because in the final calculation of the
 155 long-term mean (for power: $\bar{P} = \int f_L(P) P dP$), the bins are all aggregated. Furthermore, any point masses in the distribution (for wind farm power, zero and rated power are point masses) need to be at bin center values. This is to ensure that their (often high) occurrence are assigned their correct point mass values.

3 Methods and data

3.1 LES setup

160 The employed LES code, named the Atmospheric Simulation Platform for Innovation, Research, and Education (ASPIRE) has gradually evolved from its root, the Dutch Atmospheric Large-Eddy Simulation (Heus et al., 2010). Key developments were its porting to Graphics Processing Units (GPUs) (Schalkwijk et al., 2012, 2015), coupling to reanalysis- or large-scale forecast weather data, and most recently, the transition from periodic boundary conditions to open boundary conditions. In the current setup, the core LES domain is nested in a coarser mesoscale-type simulation with a resolution of 1.5 km, which
 165 is directly coupled to ERA5 with open boundary conditions. This coarser simulation has the same model formulation as the LES, except for turbulence, which is completely parametrized. In this way, the model setup includes the basic elements of meso-scale dynamics and gradients, such as fronts or land-sea transitions, which is problematic in a periodic simulation. For this study, an LES domain (Fig. 1) of 30.72 km by 30.72 km and a horizontal resolution of 120 m is chosen. Although this can be considered a coarse resolution, Baas et al. (2023) showed that refining to 60 m has a relatively small effect on
 170 total aerodynamic losses of a 770 MW wind farm. The vertical spacing of the 64 model levels starts at 30 m at the surface, and stretches exponentially to the domain top at 3 km. The coarser simulation around the LES has a domain of 144 km and a horizontal resolution of 1.5 km. Its 64 vertical levels start with a spacing of 40 m and stretch exponentially to the top at 8 km.




Figure 1. The simulation setup. a) the LES (small orange square) is nested in a coarser simulation (large orange square) on the North Sea. b) The LES domain with the wind farm layout (dots).

The domains are on the southern North Sea, centered at 53.22°N, 3.22°E, and basic meteorological quantities are written at 10-minute intervals at that location. For the long-term correction, hourly averaged values will be used. The simulation period is 2010 - 2019, each day of which is simulated separately with a spin-up time of 2 hours.

3.2 Wind farm modelling

A hypothetical wind farm with a regularly spaced square layout of 8 by 8 turbines is included in the LES. The turbine type is the 15 MW offshore reference wind turbine of the International Energy Agency, described in Gaertner et al. (2020), and the turbines are spaced six times their rotor diameter ($6 \cdot 240 \text{ m} = 1440 \text{ m}$) (Fig. 1).

180 Turbines are implemented in the LES according an actuator disk model (Meyers and Meneveau, 2010; Calaf et al., 2010). In this approach, grid-specific power- and thrust coefficients of the turbine are first calculated offline from the manufacturer's information. During the simulation, the power production of each individual turbine as well as its force on the flow can be determined. In this way, turbines produce individual wakes and interact.

Two separate LES runs are performed for this study: one with active wind turbines, named the *realistic* run; and one where 185 the wind turbines do not exert any force on the flow, named the *free stream* run. In the following, we will refer to wind and power production from those runs as realistic power or wind and free stream power or wind, respectively. The turbines in this



free stream run have their thrust coefficient set to zero, meaning that they produce power, but no wakes; and therefore do not interact. A more elaborate description of the wind farm modelling can be found in Baas et al. (2023).

3.3 Observation data

190 10-minute wind anemometer data during 2010-2019 from the K13 offshore platform (53.22°N, 3.22°E, 75.3 m height) were obtained via the application programming interface of the Royal Netherlands Meteorological Institute (KNMI) at <https://datapatform.knmi.nl/dataset/windgegevens-1-0> (last accessed 2 May 2024). The original data were unvalidated and contained periods when the wind speed erroneously decreases to zero. These were removed, together with all days that did not have complete data. These two cleaning steps removed 25 % of the data points.

195 3.4 Day selection techniques

A simple set of day selection techniques is applied to investigate the accuracy of the long-term correction methods as a function of LES run time (scenario 2). More involved techniques exist to find a sample of days that is representative of the wind climate (see e.g. Rife et al. (2013)), but their application is not the object of this study.

Day selection techniques may have an inherent source of randomness (such as simply selecting random days), and applying
200 them many times gives an indication of the error statistics of the long-term correction method. Other methods are deterministic, and some form of spread or randomness needs to be introduced in order to gauge the error statistics of the long-term correction method. The following day selection techniques and their associated introduced source of spread are tested in this research:

- *consecutive*: a number of consecutive days are selected. Spread is introduced by starting on a random day, ensuring the sample falls within the time span of the LES.
- 205 – *random*: a number of random days are selected. Spread is introduced by using different random realizations.
- *ordered*: all days are ordered (sorted) based on their mean ERA5 100 m wind speed. Days are then equidistantly chosen from this series, in order to end up with the desired sample size. Spread among different samples is introduced by first excluding 365 random days from the 10 years, and then taking the equidistant sample.
- *k-means*: a standard *k*-means clustering method is applied on daily mean ERA5 values of zonal and meridional 100
210 m wind. Spread is introduced by first excluding 365 random days from the 10 years, and then applying the *k*-means algorithm.

4 Results and discussion

The following sections first describe the general performance of the realistic and free stream 10-year LES runs, in terms of wind statistics and comparison to observations. Then, as an illustration of the long-term correction method, Sect. 4.2 gives the
215 illustration of using 2010 to estimate the mean power production of 2010-2019 as estimated by the LES. This leads the way




Figure 2. Basic validation of the free stream 10-year LES run. a) 10-minute free stream LES wind speed against observed wind speed at 75.3 m and standard error metrics, b) 1-h free stream LES wind speed at 75.3 m against ERA5 wind speed at 100 m, and c) histograms of 10-minute free stream LES and observed wind speed at 75.3 m during the observations-LES overlap times.

to using many consecutive years to estimate the long-term mean LES power production (scenario 1), from which error metrics that describe the performance of the method can be calculated. Similar error metrics will be presented in Sect. 4.3, in which the long-term correction method will be applied to the different day selection techniques (scenario 2). Finally, Sect. 4.4 shows how observations can be integrated, which will give estimates of the (bias-free) real long-term mean power production (scenario 3).

220 4.1 Characterization and validation of the 10 y LES

Figure 2 shows basic validation statistics of the free stream LES run with observations and ERA5 wind. In general, the LES captures the wind conditions satisfactorily, despite its bias of $-0.36 m s^{-1}$, which is typical in this application.

To illustrate the approach of the free stream and realistic run, Fig. 3 shows the joint (for the realistic run) and marginal probability density functions (PDFs) (for both runs) of power production of the wind farm and wind in the center of the domain
 225 at 75.3 m height. The joint PDF can be read as a 'wind farm power curve', i.e.; it shows the mapping from wind conditions to power production. This mapping is not unique: for a given wind speed in the center of the park, there is a considerable range of power production values that are plausible. This reflects the combined effects of other factors than wind, such as stability and wind direction, that indirectly influence the power production through their effects on the turbine wakes. The relative difference in mean power production between the free stream and realistic run represents all internal aerodynamic losses and has a value
 230 of 17.5 %. This is mainly due to lower occurrence of rated power conditions in the realistic run. Wind conditions are similarly affected by including realistic turbines in the LES: the mean wind decreases by 19 %, and the wind PDF loses its characteristic Weibull shape.




Figure 3. Illustration of the simulation approach. Center panel: joint PDF of LES power production and wind speed in the center of the domain at 75.3 m in the realistic run. Top panel: marginal PDFs of that wind speed for the realistic and free stream runs. Right panel: marginal PDFs of power production for the realistic and free stream run. The top and right panels are the integral of the joint PDF along the vertical and horizontal axes. Dots in the center panel indicate the mean values, and percentages the decrease of those values due to the realistic inclusion of turbines in the simulation.

4.2 Long-term correction of 365 consecutive days for climatological variability

In this section, the performance of the long-term correction method of 365 days to 10 years will be described. This entails
 235 evaluating the integrals in eqns. 5 and 6 and is an application of scenario 1 as described in the introduction. Before statistically



evaluating the performance of the long-term correction method of many sets of 365 consecutive days, it is insightful to consider a graphical representation of the method and to validate the method's assumptions. To those ends, Figure 4a-b show the PDF's of wind and power production during an arbitrary year (2010) and the full run period (2010-2019), together with the estimated long-term PDF of power by applying eqn. 5. The year 2010 had below average wind speeds, which is reflected in a lower than average occurrence of rated power. The long-term correction method produces a power production PDF (black line in Fig. 4b) which visually matches the real long-term power production PDF, giving a basic first confirmation of the method's validity. Figure 4c shows, for the years 2010 - 2019, the sensitivity of the long-term power estimate to the binning of wind in eqn. 2. In the range of about 0.5 m s^{-1} to 1 m s^{-1} , there is a low sensitivity to the wind bin width. Outside of this range, the assumptions behind the long-term correction method break down. From now on, therefore, a wind bin width of 0.75 m s^{-1} will be chosen. A simple visualization of the central assumption in eqn. 4 is shown in Figure 4d: within each wind bin starting between 3 m s^{-1} and 12 m s^{-1} , this shows the PDF's of power production, i.e. $h_{L|ERA}(P, M)$, for each individual year in 2010-2019. Also, the same PDFs but for the entire period 2010-2019 are shown ($\hat{h}_{L|ERA}(P, M)$). If eqn. 4 was fulfilled perfectly, the PDFs within each wind bin would coincide. Although this perfect match is not observed, their general shapes largely agree, justifying the use of the assumption.

To gain more statistical insight into the performance of the current method, it was applied on 329 series of 365 consecutive days within the 10-year LES run (each starting 10 days after the previous one); for realistic power production, free stream power production, realistic wind in the center of the LES domain at 75.3 m, and specific humidity at the same location. This allows calculation of the mean absolute error (MAE) of the long-term correction method. Figure 5 shows timeseries and their histograms of the set of consecutive days, together with their long-term corrected counterpart, and several statistical metrics. Typically, interannual variability of uncorrected variables is about 4 % of the mean, which, for power, corresponds to previously found values (Pryor et al., 2018) in a study about wind farms in the US. Applying the long-term correction removes much of that variability and produces a timeseries centered around the long-term mean value (horizontal black lines). For free stream power, realistic power, and realistic wind; the method gives MAEs of 0.36 %, 0.35 %, and 0.69 % of their long-term means, respectively. The 95th percentiles of the absolute errors are around 0.8 % (realistic and free stream power), and 1.57 % (realistic wind) of the long-term means. Long-term correction of specific humidity (bottom panel) is not successful: almost no variability is removed by doing the long-term correction. This indicates that there should be a clear mapping between the variable to be long-term corrected and wind.

4.3 Day selection techniques and their effect on long-term correction

When there is no need to run consecutive days in the LES (scenario 2 in the introduction), the LES run period can be chosen in order to optimize the estimation of the long-term mean power production or wind. In this section, simple methods of 'smart day selection' will be combined with the long-term correction method to get to such estimates. It should be noted that this approach of day selection is also viable without a long-term correction method. In that case, the aim is to choose days which are representative of the long-term climate (e.g. Rife et al. (2013)), and no statistical correction is applied on the simulation




Figure 4. Illustration of the long-term correction method. a) ERA5 100 m wind distributions for 2010 and 2010-2019, and b) realistic LES power production distributions for 2010 and 2010-2019, and including the distribution for 2010-2019 as estimated by the long-term correction method from 2010. c) for all years 2010-2019 (increasing from blue to yellow) the long-term mean power as estimated by the long-term correction method, as a function of wind bin size. The chosen value of 0.75 m s^{-1} is indicated with the vertical line. d) for wind bins starting between 3 m s^{-1} and 12 m s^{-1} (indicated by the different colors, increasing from left to right), the power distribution within that wind bin for the years 2010-2019 (different lines). The long-term counterparts are plotted with dotted lines.

results.

270

The attention will now be limited to realistic power production and wind speed in the middle of the LES domain. From the 10 years of LES output, and for a range of days between 10 and 365, the day selection techniques described in Sect. 3 were applied 500 times, after which the long-term correction method was applied on the resulting samples. Resulting MAEs and 95th percentiles of the absolute errors are shown as a function of sample size in the right panels of Fig. 6. The left panels show




Figure 5. Timeseries and their histograms of long-term corrected series of 365 consecutive days. Left panels: long-term correction of (a-d) free stream power, realistic power, wind, and specific humidity. Plotted values refer to the previous 365 days. Blue lines are the non-corrected values, orange the corrected values, and the horizontal grey lines show the long-term mean. Right panels show histograms of the timeseries. In the left panels, μ and σ refer to the means and standard deviations of the uncorrected timeseries, and in the right panels, the means and 95th percentiles of the absolute errors of the long-term corrected values are given.

the uncorrected versions, which reveal the qualitative difference between the four day selection techniques. For a sample larger than roughly 40 days, the MAE of the uncorrected power and wind decreases in the order: 'consecutive', 'k-means', 'random', and 'ordered'. This reflects each method's representativeness of the long-term climate. By construction, < 365 consecutive days are all within the same seasonal cycle, and therefore are not representative of the long-term climate. Also, a *k*-means algorithm applied on the two components of the horizontal wind does not represent the underlying distribution, because it homogeneously samples all possible wind conditions, without taking into account their probability density. Only the 'ordered'



method is specifically constructed to sample the wind condition weighted by their occurrence frequency, thereby making a sample which has a mean wind close the climatological value (i.e., a low MAE in the left panels of Fig. 6).

However, after applying the long-term correction method, the difference between all techniques, except for 'consecutive', has almost vanished. For the 'ordered' method, there is only a marginal improvement in the MAE compared to its uncorrected counterpart, but for the other techniques, it is substantial. For example, long-term correction of 100 random days of LES can, on average, decrease the error in estimating the long-term mean wind from 4 % to 1 %. For consecutive days, it can be decreased from 11 % to 5 %. Moreover, the previous section showed that running 365 consecutive days gives an MAE of approximately 0.35 % of the long-term mean (for power). With the random, ordered, or k -means method, this value can already be attained at approximately 200 days. Simulating more days only marginally improves the MAE, which is qualitatively consistent with the typical $1/\sqrt{N}$ behaviour of convergence of the standard error. Furthermore, if a MAE of 1 % is tolerable, fewer than 50 simulation days are required.

Even after long-term correction, the 'consecutive' method remains distinctly different from the other three, yielding considerably higher MAEs. Since it is the only method that does not select days from different years (or from different seasons, if the sample size is well below one year), this strongly suggests that choosing days from different years and seasons is the most important element in designing a day selection technique for long-term correction.

4.4 Including observations: correction of LES bias and climatological variability

As a final step, this section explores integration of wind observations in the long-term correction method (scenario 3). This involves performing an MCP procedure with observation data and reanalysis data, and then evaluating the integral in eqn. 7. The key difference with scenarios 1 and 2 is the use of the conditional probability $h_{L|FSL}(P, M)$, i.e. the wind farm power of the realistic run, given the wind in the free stream run. In contrast to scenarios 1 and 2, therefore, integrating observations in the long-term correction procedure strictly requires the free stream LES run. The resulting long-term corrected values are harder to validate, because the simulation setup with a hypothetical wind farm precludes the use of observed wind farm power or observed disturbed wind speed.

As an illustration, a standard MCP procedure was performed on observations from 2010 (resampled to one hour), where the observed wind is linearly fitted to the reanalysis wind, in 16 wind direction sectors. Figure 7 shows scatter plots of the observed wind, the ERA5 wind, the free stream LES wind, and the MCP wind. By construction, the MCP wind has a zero bias with respect to the observations. The bias between the free stream LES and the MCP is very similar to the bias between the free stream LES and the observations, confirming that the MCP procedure constructs a 'quasi-observation' timeseries.

Long-term correction according to eqn. 7 was then applied for power and realistic wind (using the conditional probability between realistic LES wind and free stream LES wind in the latter case) for 329 series of 365 consecutive days, with the previously constructed MCP wind (based on 2010). This gives values for power and wind which are corrected for both interannual




Figure 6. Performance of the long-term correction method for power (top) and wind (bottom) as a function of simulation period, for different day selection techniques. The left panels show the mean and 95th percentile of the absolute errors of the uncorrected samples, and the right panels show the same after applying the long-term correction method.

variability and bias with respect to observations. It is impossible to present error metrics of the long-term corrected values of realistic wind and power, because the simulated windfarm is hypothetical. However, some useful insights can be derived from timeseries of the long-term corrected values (Fig. 8). The difference between the long-term mean free stream LES wind and the long-term mean MCP wind reflects the LES bias of about -0.36 m s^{-1} . Also the difference between the long-term mean realistic LES wind and the long-term corrected wind takes on this approximate value. I.e., the long-term correction method corrects a similar bias in the free stream as in the realistic case. For power, a similar pattern is observed: the long-term correction adjusts the realistic and free-stream power by roughly the same amounts ($\sim 30 \text{ MW}$).

5 Conclusions

This work presented methods to estimate long-term mean wind and wind farm power production from shorter LES simulations, applied to three increasingly complex scenario's that are typical in the practice of WRA. Being applications of Bayes' rule, the methods are simple, based on physical arguments, and the underlying assumptions can be verified. Furthermore, they can be




Figure 7. Illustration of MCP. a) 100 m ERA wind against 75.3 m observed wind during 2010, b) 75.3 m observed wind against MCP wind during 2010, and c) free stream LES wind against MCP wind during 2010-2019.




Figure 8. Long-term correction of 75.3 m realistic wind (a) and power (b) including observations. a) the top cluster of curves show free stream wind, including the LES, its long-term mean (horizontal blue line), and the mean MCP wind. The bottom cluster shows the realistic LES wind and long-term mean, together with its estimated long-term value (green line). b) like a), but for power production.



not limited to LES, but can also be applied to other (wake) models, numerical weather prediction models, or observation data. Data from a 10-year LES run showed that long-term correction of 365 days of pure LES wind farm power can estimate its 10-year counterpart with a MAE of around 0.35 % of the long-term mean, approximately one tenth of the interannual variability. When the run period can be freely chosen, similarly accurate estimates can be attained at periods of around 200 days. Moreover, fewer than 50 simulation days are needed to reach a MAE of 1 %. The best estimates of long-term means are achieved by choosing a sample across different years and seasons, for example with the 'ordered' method, which produces a sample that is representative of the long-term climate. Nevertheless, even randomly chosen days are diverse enough to provide a good sample for long-term correction. Only for consecutive days, which are by construction during the same year, the errors are considerably larger.

Finally, it was shown that introducing observations can add value in estimating long-term means of power and wind, by correcting a possible bias in the LES. This approach is more expensive, however, because an additional free stream run is needed. However, such a free stream run provides additional benefit, because it allows quantification of the total wake losses of the wind farm. Furthermore, because WRA commonly is a combination of modelling and on-site observations, this method fits well within its current practices. Although validating this method against actual wind farm data was outside the scope of this research, quantifying real operational wind farm variability remains a challenge and an ongoing effort. Combining real wind farm data with methods presented in this work would therefore be a promising route for further research.

Code and data availability. The 10-year LES output data at one hour frequency, ERA5 wind at the same location, as well as Python code to do long-term correction according to scenario 1 are available in a Git repository, archived at Zenodo (Postema, 2024): <https://zenodo.org/doi/10.5281/zenodo.11097255>.

Author contributions. BP performed the simulations, implemented the long-term correction method, and wrote the manuscript. The concept of long-term correction was formalized by BP based on earlier work by RV and PvD. RV, PvD, PB, and HJ provided ideas, corrections, and modifications. HJ and PvD are the main developers of the Aspire model.

Competing interests. All authors are employed at Whiffle BV, a limited liability company.



References

- 350 Baas, P., Verzijlbergh, R., Dorp, P. V., and Jonker, H.: Investigating energy production and wake losses of multi-gigawatt offshore wind farms with atmospheric large-eddy simulation, *Wind Energy Science*, 8, 787–805, <https://doi.org/10.5194/wes-8-787-2023>, 2023.
- Bieringer, P. E., Piña, A. J., Lorenzetti, D. M., Jonker, H. J., Sohn, M. D., Annunzio, A. J., and Fry, R. N.: A graphics processing unit (GPU) approach to large eddy simulation (LES) for transport and contaminant dispersion, *Atmosphere*, 12, <https://doi.org/10.3390/atmos12070890>, 2021.
- 355 Breton, S. P., Sumner, J., Sørensen, J. N., Hansen, K. S., Sarmast, S., and Ivanell, S.: A survey of modelling methods for high-fidelity wind farm simulations using large eddy simulation, *Philosophical Transactions of the Royal Society A: Mathematical, Physical and Engineering Sciences*, 375, <https://doi.org/10.1098/rsta.2016.0097>, 2017.
- Calaf, M., Meneveau, C., and Meyers, J.: Large eddy simulation study of fully developed wind-turbine array boundary layers, *Physics of Fluids*, 22, <https://doi.org/10.1063/1.3291077>, 2010.
- 360 Carta, J. A., Velázquez, S., and Cabrera, P.: A review of measure-correlate-predict (MCP) methods used to estimate long-term wind characteristics at a target site, *Renewable and Sustainable Energy Reviews*, 27, 362–400, <https://doi.org/10.1016/j.rser.2013.07.004>, 2013.
- Gaertner, E., Rinker, J., Sethuraman, L., Zahle, F., Anderson, B., Barter, G., Abbas, N., Meng, F., Bortolotti, P., Skrzypinski, W., Scott, G., Feil, R., Bredmose, H., Dykes, K., Shields, M., Allen, C., and Viselli, A.: Definition of the IEA Wind 15-Megawatt Offshore Reference Wind Turbine Technical Report, www.nrel.gov/publications, 2020.
- 365 Gilbert, C., Messner, J. W., Pinson, P., Trombe, P. J., Verzijlbergh, R., van Dorp, P., and Jonker, H.: Statistical post-processing of turbulence-resolving weather forecasts for offshore wind power forecasting, *Wind Energy*, 23, 884–897, <https://doi.org/10.1002/we.2456>, 2020.
- Göçmen, T., Laan, P. V. D., Réthoré, P. E., Diaz, A. P., Larsen, G. C., and Ott, S.: Wind turbine wake models developed at the technical university of Denmark: A review, *Renewable and Sustainable Energy Reviews*, 60, 752–769, <https://doi.org/10.1016/j.rser.2016.01.113>, 2016.
- 370 Hersbach, H., Bell, B., Berrisford, P., Hirahara, S., Horányi, A., Muñoz-Sabater, J., Nicolas, J., Peubey, C., Radu, R., Schepers, D., Simons, A., Soci, C., Abdalla, S., Abellan, X., Balsamo, G., Bechtold, P., Biavati, G., Bidlot, J., Bonavita, M., Chiara, G. D., Dahlgren, P., Dee, D., Diamantakis, M., Dragani, R., Flemming, J., Forbes, R., Fuentes, M., Geer, A., Haimberger, L., Healy, S., Hogan, R. J., Hólm, E., Janisková, M., Keeley, S., Laloyaux, P., Lopez, P., Lupu, C., Radnoti, G., de Rosnay, P., Rozum, I., Vamborg, F., Villaume, S., and Thépaut, J. N.: The ERA5 global reanalysis, *Quarterly Journal of the Royal Meteorological Society*, 146, 1999–2049, <https://doi.org/10.1002/qj.3803>, 2020.
- 375 Heus, T., Van Heerwaarden, C. C., Jonker, H. J., Siebesma, A. P., Axelsen, S., Van Den Dries, K., Geoffroy, O., Moene, A. F., Pino, D., De Roode, S. R., and Vilà Guerau De Arellano, J.: Formulation of the Dutch Atmospheric Large-Eddy Simulation (DALES) and overview of its applications, *Geoscientific Model Development*, 3, 415–444, <https://doi.org/10.5194/gmd-3-415-2010>, 2010.
- Kantharaju, J., Storey, R., Julian, A., Delaunay, F., and Michaud, D.: Wind resource modelling of entire sites using Large Eddy Simulation, vol. 2507, Institute of Physics, ISSN 17426596, <https://doi.org/10.1088/1742-6596/2507/1/012015>, 2023.
- 380 Laan, M. P. V. D., Andersen, S. J., Réthoré, P. E., Baungaard, M., Sørensen, J. N., and Trolborg, N.: Faster wind farm AEP calculations with CFD using a generalized wind turbine model, vol. 2265, Institute of Physics, ISSN 17426596, <https://doi.org/10.1088/1742-6596/2265/2/022030>, 2022.



- Locascio, M. J., Bay, C. J., Bastankhah, M., Barter, G. E., Fleming, P. A., and Martínez-Tossas, L. A.: FLOW Estimation and Rose Superpo-
 385 sition (FLOWERS): An integral approach to engineering wake models, *Wind Energy Science*, 7, 1137–1151, <https://doi.org/10.5194/wes-7-1137-2022>, 2022.
- Mehta, D., van Zuijlen, A. H., Koren, B., Holierhoek, J. G., and Bijl, H.: Large Eddy Simulation of wind farm aerodynamics: A review, *Journal of Wind Engineering and Industrial Aerodynamics*, 133, 1–17, <https://doi.org/10.1016/j.jweia.2014.07.002>, 2014.
- Meyers, J. and Meneveau, C.: Large Eddy Simulations of large wind-turbine arrays in the atmospheric boundary layer, ISBN 9781600867392,
 390 <https://doi.org/10.2514/6.2010-827>, 2010.
- Postema, B.: Long-term correction, <https://doi.org/10.5281/zenodo.11097662>, 2024.
- Pryor, S. C., Shepherd, T. J., and Barthelmie, R. J.: Interannual variability of wind climates and wind turbine annual energy production, *Wind Energy Science*, 3, 651–665, <https://doi.org/10.5194/wes-3-651-2018>, 2018.
- Rife, D. L., Vanvyve, E., Pinto, J. O., Monaghan, A. J., Davis, C. A., and Poulos, G. S.: Selecting representative days for more ef-
 395 ficient dynamical climate downscaling: Application to wind energy, *Journal of Applied Meteorology and Climatology*, 52, 47–63, <https://doi.org/10.1175/JAMC-D-12-016.1>, 2013.
- Schalkwijk, J., Griffith, E. J., Post, F. H., and Jonker, H. J.: High-performance simulations of turbulent clouds on a desktop PC, *Bulletin of the American Meteorological Society*, 93, 307–314, <https://doi.org/10.1175/BAMS-D-11-00059.1>, 2012.
- Schalkwijk, J., Jonker, H. J., Siebesma, A. P., and Bosveld, F. C.: A year-long large-eddy simulation of the weather over Cabauw: An
 400 overview, *Monthly Weather Review*, 143, 828–844, <https://doi.org/10.1175/MWR-D-14-00293.1>, 2015.
- Stoll, R., Gibbs, J. A., Salesky, S. T., Anderson, W., and Calaf, M.: Large-Eddy Simulation of the Atmospheric Boundary Layer, *Boundary-Layer Meteorology*, 177, 541–581, <https://doi.org/10.1007/s10546-020-00556-3>, 2020.
- van Stratum, B. J., van Heerwaarden, C. C., and Vilà-Guerau de Arellano, J.: The Benefits and Challenges of Downscal-
 405 ing a Global Reanalysis With Doubly-Periodic Large-Eddy Simulations, *Journal of Advances in Modeling Earth Systems*, 15, <https://doi.org/10.1029/2023MS003750>, 2023.
- Verzijlbergh, R. A.: Atmospheric flows in large wind farms, *Europhysics News*, 52, 20–23, <https://doi.org/10.1051/epr/2021502>, 2021.